

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

Fax : 23412593, E-mail: cfhq. dlfire@nic.in Tel :- 011-23414333

No. F6/MS/DFS/EH/2013/NDZ/642

Dated: 28/07/13

FIRE SAFETY CERTIFICATE

Certified that the Restaurant in the name and style of Gem Restaurant, at ground floor and 1st floor located at 1050, Main Bazar, Pahar Ganj, New Delhi-110055 comprised of ground plus three upper floors was granted NOC by this department vide letter No. F6/DFS/MS/EH/2012/2983 dated 16-08-2012. The premises was re-inspected by the officer concerned of this department on 10-07-2013 in the presence of Mr. Amardeep Singh (owner) and status of restaurant/building is as under :- The restaurant is comprised of ground floor, 1st floor and 2nd floor and found that the said restaurant building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for Class D (Assembly) occupancy with effect from 28/07/2013 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 28/07/13. at New Delhi by.



(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

96
Recd
26-7-13

Copy to :-

1. M/s Gem Restaurant, 1050, Main Bazar, Pahar Ganj, New Delhi-110055
2. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi - 110049.
- 3.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

41/13

INSPECTION REPORT

1. Name & address of the building : Gem Restaurant, 1050, Main Bazar, Pahar Ganj, New Delhi-110055
2. Type of Occupancy : Eating House (Floor Addition)
3. Type of Case : Old Case/Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/EH/2012/2983 dated 16-08-2012
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 10-07-2013
7. Name of the Inspecting Officer : Sh. D.S. Yadav (D.O.)
8. Name and designation of Officer
from the building side : Mr. Amardeep Singh (owner)
9. Year of Construction : 2005 Starting Year
10. Applicant's letter No. : Nil dated Nil

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site (PSS Area)	Remarks MR/NMR (Old Case)
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width 	accessible	More then 6 mtrs.	MR
		N/A	Directly accessible from main road	N/A
	<ul style="list-style-type: none"> • Width of internal road 	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	01	01	MR
		N/A	N/A	N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors (Two Exit) • Basements 	90 cms. to 110 cms.	Provided	MR
		N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	N/A	N/A
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A

N/14

4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour	N/A	MR
		12 a/c per hour	Exhaust Fan	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	10 ISI marked	10 Co2 & A.B.C. type. Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 M 5 mm	01 Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System/Intercom	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	N/A Required N/A	N/A Provided N/A	N/A MR N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	N/A Yes Yes	100 mm 01 at ground floor Provided	N/A MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 450 LPM & 180 LPM 40 Mtrs. Each Required Required	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A Provided Provided Provided Provided	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A MR MR MR MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity Draw of connection Fire service inlet 	N/A N/A Required	N/A N/A Provided	N/A N/A MR

11/15

Gem Restaurant, 1050, Main Bazar, Pahar Ganj, New Delhi-110055

	<ul style="list-style-type: none"> ➤ Access to tank • Overhead Tank capacity 	Required 10000 ltrs.	Provided 10000 ltrs	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			MR
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	Required	Provided (DG set)	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Batter backup ➤ Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	One co2 type fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
 Name
 Designation

Signature of the Inspecting Officer
Dharmvir Singh Yadav
 Name
 Designation *Divisional Officer*