

C-18

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2013/W2/620 Dated: 25/07/2013

FIRE SAFETY CERTIFICATE

Certified that the Happy Child Modern Public School is comprised of Ground floor only located at Khera Garhi, Delhi owner / occupied by Happy Child Modern Public School was issued fire safety certificate letter No F-6/DFS/MS/2008/3419 dated 15/12/2008. The premises was re-inspected by the officer from this department on dated 06/07/2013 in the presence of Mrs Sophia (Principal) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of circular issued by Director of Education letter dated 17/01/2005 and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 25/07/2013 for a period of three years, subject to conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 25/07/13 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Happy Child Modern Public School, K No 63/19, Sirasapur Road, Khera Garhi, Delhi-82.
2. The Director of Education, Old Secretariat, Delhi

N/3

(GF only in 2008)

INSPECTION REPORT

1. Name & address of the building: HAPPY CHILD MODERN Public School.
K.N. NO 63/119 Sisaq Pura Rd. Khora Sashi Selu
(Previously known as HAPPY CHILD Pub. School)
2. Type of Occupancy: Educational
3. Type of Case: New Case / Renewal
4. Details of previous NOC: F-C/DFS/MS/2008/3419 dtd 15/12/08
5. Fire Safety directives letter No: Dir of Edu.
6. Date of inspection: 6/7/2013
7. Name of the Inspecting Officers: ADO K.K. Saxena / ADO Bawang
8. Name and designation of officers from the building side: Mrs Sophia (Principal)
9. Year of Construction: (GF only)
10. Applicant's letter No. MIL dtd 19/3/2013 (GF only)
- PA - 9672 sq yds CA - 572 sq yds, NOR - 7, NOT-1+6 NOS - 200

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	<p>Accessible</p> <p>-</p> <p>-</p>	<p>Accessible</p> <p>-</p> <p>-</p>	<p>m/r</p> <p>-</p> <p>-</p>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 			
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 			
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	1m	1m	M/R
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts 			

14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

[Signature]
[Signature]
 12/11/13

Signature of the Inspecting Officer

Name

Designation

[Signature]
 K. G. SARKARIA
 ARO