

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No: F.6/DFS/MS/School/2013/ 52/635

Dated: 29/07/13

FIRE SAFETY CERTIFICATE

Certified that the building of **M.C.D Pritibha Vidyalaya**, Hari Nagar Ghanta Ghar, New Delhi -110064 comprised of ground floor plus one upper floor, having total 26 rooms (Including Class Rooms, Office & Store etc.) owned/occupied by MCD was inspected by the officer concerned of this department on 20.07.2013 in the presence of Smt. Nirupma Saxena (Principal) and found that the M.C.D have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed below.

Issued on29/07/13.....at New Delhi



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

Copy to: -

1. The Principal,
M.C.D Pritibha Vidyalaya,
Hari Nagar Ghanta Ghar, New Delhi-64.
2. Director of Education,
South Delhi Municipal Corporation
23rd floor, Dr. S.P.M Civic Centre,
Minto Road, New Delhi-110002.

N/7

(G + I floor)

INSPECTION REPORT

Name & address of the building: M.C.D Pritibha Vidyalaya, Hari Nagar Ghanta Ghar, ND-64
 Nature of Occupancy: Educational
 Type of Case: New Case/Renewal
 Details of Previous NOC: Letter No. — Dated —
 Fire Safety directives letter No: —
 Date of inspection: 20-07-2013
 Name of Inspecting Officer: ADO Sandeep Duggal
 Name and designation of officers: Smt Nirupma Sexena (Principal)
 Date of the building side: 1965
 Date of construction: Nil dated 08-07-2013.

| Minimum Standards on fire prevention and fire safety I/R 33 | Dir. Of Edu. Circular dt. 01.03.2011 | Provided at site | Remarks MR/NMR |
|---|--------------------------------------|------------------|----------------|
|---|--------------------------------------|------------------|----------------|

| Access to building | | | |
|--------------------------|------------|-------------|----|
| • Road width | Accessible | 5 mtrs | MR |
| • Gate width | — | 3.20m (Two) | MR |
| • Width of internal road | — | — | — |

| Number, Width, Type & Arrangement of Exits | | | |
|--|----|----------------|-------------|
| • Number of staircases | | | |
| • Upper Floor | 02 | 02 | MR |
| • Basements | — | — | No Basement |
| • Width of staircases | | | |
| • Upper Floor | — | 01-20m & 95cms | MR |
| • Basements | — | — | No Basement |
| • Protection of exits | | | |
| • Fire check door | — | — | — |
| • Pressurization | — | — | — |
| • No. of continuous staircases to terrace | — | one | — |
| • Width of Corridor | — | — | — |
| • Door Size | — | 01.10 m | MR |

| Compartmentation | | | |
|--------------------------------|---|---|---|
| • Fire check door | — | — | — |
| • Sealing of electrical shafts | — | — | — |
| • Fire Rating of shaft door | — | — | — |
| • Grease Curtain | — | — | — |
| • Fire Dampers | — | — | — |

| Smoke Management System | | | |
|-------------------------|-----------------|---------------------|-------------|
| • Basements | 30 a/c per hour | — | No Basement |
| • Upper floors | — | Natural Ventilation | MR |

N/8

M

| | | | |
|-----|--|-----------------------|----------|
| | 12 a/c per hour | — | — |
| 5. | Fire Extinguishers | | |
| | • Total numbers | 04 | Provided |
| | • Types | ABC + CO ₂ | MR |
| | • IS marking | ISI marked | MR |
| 6. | First-Aid Hose Reels | | |
| | • Total numbers on each floor | — | — |
| | • Length of hose reel hose | 30 m | — |
| | • Nozzle diameter | 5 mm | — |
| 7. | Automatic fire detection and alarming system | | |
| | • Type of detectors | — | — |
| | • Location of Main Panel | — | — |
| | • Location of Repeater Panel | — | — |
| | • Alternate source of power | — | — |
| | • Hooters' Location | — | — |
| 8. | MOEFA | | |
| 9. | Public Address System | | |
| 10. | Automatic Sprinkler System | | |
| | • Basement | — | — |
| | • Upper Floor | — | — |
| | • Sprinkler above false ceiling | — | — |
| 11. | Internal Hydrants | | |
| | • Size of riser/down-comer | — | — |
| | • Number of hydrants per floor | — | — |
| | • Hose Box | — | — |
| 12. | Yard Hydrants | | |
| | • Total number of hydrants | — | — |
| | • Hose Box | — | — |
| 13. | Pumping Arrangements | | |
| | • Ground Level | — | — |
| | ➤ Discharge of main Pump | — | — |
| | ➤ Head of Main pump | — | — |
| | ➤ Number of main pumps | — | — |
| | ➤ Jockey Pump out put | — | — |
| | ➤ Jockey pump head | — | — |
| | ➤ Standby Pump out put | — | — |
| | ➤ Standby Pump Head | — | — |
| | ➤ Auto Starting/Manual stopping | — | — |

N/9

| | | | | |
|-----|---|---|---|---|
| | <ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump | ✓ | ✓ | ✓ |
| 14. | Captive Water Storage for fire fighting | | | |
| | <ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity | ✓ | ✓ | ✓ |
| 15. | Exit Signage. | ✓ | ✓ | ✓ |
| 16. | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage | ✓ | ✓ | ✓ |
| 17. | Standby power supply | ✓ | ✓ | ✓ |
| 18. | Refuge Area. | | | |
| | <ul style="list-style-type: none"> ➤ Total Area ➤ Location | ✓ | ✓ | ✓ |
| 19. | Fire Control Room | | | |
| | <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans | ✓ | ✓ | ✓ |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | ✓ | ✓ | ✓ |

N/10

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers:.....~~

Note :- The school building is comprised of ground plus one upper floor
The number of students in each class are less than 45, the declaration in this regard is enclosed (letter no nil dated 20/7/13),

Sandeep
23/7/13

Signature of Inspecting Officer

Name Sandeep Duggal

Designation Asstt Divisional officer

Signature of Inspecting Officer

Name

Designation

