

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No: F.6/DFS/MS/School/2013/ 52/619

Dated: 25/07/13

**FIRE SAFETY CERTIFICATE**

Certified that the building of Maharishi Dayanand Public School, Block – 9, Arya Samaj Bhawan, Ramesh Nagar, New Delhi comprised of ground plus one upper floor, owned and occupied by Maharishi Dayanand Public School was inspected by the officer concerned of this department on 04-07-2013 in the presence of Mrs. Shashi Prabha Arya (Principal) and found that premise have complied with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 - 3398 dated 01.03.2011 issued by the Director of Education and that the school building is fit for the occupancy class "Educational" Sub division – B1 with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on 25/07/13 at New Delhi.

  
(Santokh Singh)  
Chief Fire Officer,  
Delhi Fire Service.  
cfowz.dlfire@nic.in  
Ph: 011-23414250

Copy to:-

1. The Principal,  
Maharishi Dayanand Public School,  
Block – 9, Arya Samaj Bhawan,  
Ramesh Nagar, New Delhi
2. Director of Education,  
North Delhi Municipal Corporation,  
Dr. S.P.M Civic Centre,  
Minto Road, New Delhi-110002

MC  
Oy

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

**INSPECTION REPORT**

1. Name & address of the building: Maharishi Dyanand Public School  
Block-9 Arya Samaj Bhanum, Ramesh Nagar
2. Type of Occupancy : Educational (School) <sup>ND</sup> G+1 upper floor, 13 class rooms
3. Type of Case : NEN 1 Hall for 200 students.
4. Details of previous NOC : Letter No -
5. Fire Safety directives Letter No. : F.16/Estate/14/Fire Safety/2011/3298-3398 dt 1-3-11
6. Date of inspection : 04-07-13
7. Name of the Inspecting Officer : Mukesh Verma ADD (MN)
8. Name and designation of Officer from the building side : Mrs. Shashi Prabha Arya  
(Principal)
9. Year of Construction : 1985
10. Applicant's letter No. : Nil dated 5-6-13

Total area = 1942 sq. yards, Covered area = 1382 sq. yards

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL <sup>DOB</sup> Requirements <sub>1-3-11</sub>	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	150 cms	1. 100 cms 2. 102 cms	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	No Terrace	No Terrace	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1m	Provided	MR

Hall

2 X 1.5m

2 X 1.97m

MR

1 X 1.16m

Double Door



N/A

3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A		
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour		
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	N/A	
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	5 @ 300m <sup>2</sup> ABC & CO <sub>2</sub> 2.5kg ISI marked	9 [ 7 ABC 5kg 2 CO <sub>2</sub> 4.5kg ] ABC & CO <sub>2</sub> Yes	MR MR MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	N/A		
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	N/A		
8.	MOEFA	N/A		
9.	Public Address System	N/A		
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	N/A		

11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>• Size of riser/down- comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>		N/A	
12	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>		N/A	
13	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>		N/A	
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> <li>➤ Draw of connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>		N/A	
15	Exit Signage			
			N/A	
16	Provision of Lifts			

N/A

	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>			
17.	Standby power supply		N/A	
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>		N/A	
19.	Fire control room			
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Batter backup</li> <li>➤ Building Floor Plans</li> </ul>		N/A	
20.	Special Fire Protection Systems for Protection of special Risks, if any;		N/A	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted at serial numbers~~ .....

Signature of the Inspecting Officer

Name *Mukesh Verma*

Designation *ADD(MN)*

Signature of the Inspecting Officer

Name

Designation