

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**

**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**


Fax: 011-23412593, Email: [cfohq.dfire@nic.in](mailto:cfohq.dfire@nic.in), Ph. 011-23414333

No. F.6/DFS/MS/Club/2013/ 540

DATED: 09/07/13

**FIRE SAFETY CERTIFICATE**

Certified that M/s New Friends Club, New Friends Colony, Mathura Road, New Delhi, comprised of basement, lower ground, upper ground plus two upper floors was granted NOC by this department vide letter No. F6/DFS/MS/2010/1415 Dated 13.05.2010. The premises was re-inspected by the officer concerned of Delhi Fire Service on 28/06/2013 in the presence of Mr. Mahesh Arora, G.Manager of the club and observed that fire safety norms as required under Rule 33 of Delhi Fire Service Rules, 2010 are deemed complied and that the building / premises is fit for occupancy class-D "Assembly building (Club)" **(NOC renewed for Basement- Swimming pool , Lower ground- Offices, Activity rooms etc., upper ground- Restaurant, Bar and lobby, 1<sup>st</sup> floor- Restaurant, Meeting room/Card Room and 2<sup>nd</sup> floor- 6 guest rooms)** with effect from 09/07/13 for a period of THREE years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

  
(Dr. G.C. Misra)  
Chief Fire Officer  
Delhi Fire Service

Copy to: -

1. The Addl. C.P. (Lic.), First Floor, PS Defence Colony, New Delhi.
2. Mr. Mahinder Singh (G. Secretary), M/s New Friends Club, New Friends Colony, Mathura Road, New Delhi-110025

**Conditions for the validity of Fire Safety Certificate**

1. All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The Basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1	Name & address of the building	M/s New Friends Club, New Friends Colony, Mathura Road, New Delhi-110025.		
2	Type of Occupancy	Assembly "D" Club		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS/2010/1415 Dated 13.05.2013		
5	Fire safety directives letter No	No		
6	Date of inspection	28.06.2013		
7	Name of the inspecting Officers :	D.O. (South) D.P. Bhardwaj,		
8	Name and designation of officers from the building side	Mr. Mahesh Arora (G. Manager )		
9	Year of construction		<b>Basement, lower ground, upper ground and two upper floors</b>	
10	Applicant's letter No.	Nil dated 31.05.2013		

**Old Case**

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
--------	---	-----------------	------------------	------------------

<b>1</b>	<b>Access to building</b>			
	1) Road width	Required	20 Mtr Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A

<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	Old Case	2 Nos	MR
	2. basements	Old Case	3 Nos	MR
	<b>b. Width of staircase</b>			
	1. Upper floors	Old Case	1.6 & 1.10 Mtr	MR
	2. basements	Old Case	1.5, 2.0 & 1.10 Mtr	MR
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Old Case	One	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	N/A	N/A	N/A

<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

<b>4</b>	<b>Smoke Management system.</b>			
	basement	30 a/c per hour 12 a/c per hour	Exhust Fans Provided	MR
	upper floors		Natural Ventilation	MR

<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers		25 Nos	MR
	Types		ABC, Co2, water Co2	MR
	ISI marking	ISI	Yes	MR

<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	2 No.	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR

7 Automatic fire detection and alarming system			
	Type of detectors	Required	Provided (Smoke/ Heat) MR
	location of Main Panel	Required	Provided ( Lower Ground) MR
	location of Repeater panel	N/A	N/A
	Alternate source of power	Required	Battary Backup MR
	hooter's location	Required	Provided MR
8	<b>MOEFA</b>	Required	Provided MR
9	<b>Public Address System.</b>	Required	Provide MR
10	<b>Automatic Sprinkler System.</b>		
	basement	Required	Provided MR
	upper floors	Old Case	Resturant & Bar Provided MR
	sprinkler above false ceiling	N/A	N/A
11	<b>Internal Hydrants</b>		
	Size of riser/down-corner	Required	Provided MR
	Number of Hydrants per floor	Required	Provided MR
	hose Box	Required	Provided MR
12	<b>Yard Hydrants.</b>		
	total number of hydrants	N/A	N/A
	hose box	N/A	N/A
13	<b>Pumping arrangements</b>		
	<b>1. Ground level/ Terrace level</b>		
	a. Discharge of main Pump	N/A	N/A
	b.Head of main pump	N/A	N/A
	c.Number of main pumps	N/A	N/A
	d.jockey pump out put	N/A	N/A
	e.jockey pump head	N/A	N/A
	f. Standby Pump output	N/A	N/A
	g.Stanby Pump head	N/A	N/A
	h.Auto Starting/Manual stopping	N/A	N/A
	pump house access	N/A	N/A
	<b>2.Terrace level</b>		
	a. Discharge of pump	Required	450 & 180 LPM MR
	b. head of the pump	Required	35 Mtr MR
	c. Power supply	Required	Provided MR
	d. Auto starting of pump	Required	Provided MR
14	<b>Captive water storage for fire fighting</b>		
	1. Underground tank capacity	N/A	N/A
	a. Draw-off connection	N/A	N/A
	b. fire service inlet	N/A	N/A
	c.Access to tank	N/A	N/A
	Over head tank Capacity	Old Case	10,000 ltr Provided MR
15	<b>Exit Signage.</b>	Required	Provided MR
16	<b>Provision of lifts.</b>		
	a. Pressurization of lift shaft	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A
	c. communication in lift car	Required	Provided MR
	d. Fireman's grounding switch	Required	Provided MR
	e. Lift signage	Required	Provided MR
17	<b>Standby power supply</b>	Required	Provided MR
18	<b>Refuge Area.</b>	Not Required	
	total area		
	location		

N/13

19	<b>Fire control room</b>			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special risks, if any: N/A.</b>			

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule. The grant of Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers 1 & 14

**Accordingly DFA is put up for your approval and signature please.**

**Signature of the inspecting officer**

**Name D. P. Bhardwaj**



2/7/13

**Designation : Divisional Officer (South)**