

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/OFS/MS/school/2013/W2/506

Dated: 02/07/2013


FIRE SAFETY CERTIFICATE

Certified that the New Green Valley Public School, B-Block, Sant Nagar, Delhi.
Gali No. 111
is comprised of Ground + one upper floor owned and occupied by Green Valley Education & Welfare Society, have complied with the fire prevention and fire safety requirements in accordance with Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 27/06/2013 in the presence of Smt. Prerna Rautela and that the building / premises is fit for occupancy of Group Class B (Educational) with effect from 02/07/2013 for a period of three years, subject to compliance of the conditions.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 02/07/13 at New Delhi by


(Santokh Singh)
Chief Fire Officer
Delhi Fire Service
cfosz.dfire@nic.in
Tel Ph. 23414250

Copy to:

1. The Principal, New Green Valley Public School,
B-Block, Gali No. 111, Sant Nagar, Burari, Delhi
2. The Director of Education, Old Secretariat, Delhi

INSPECTION REPORT

1. Name & address of the building: New Green Valley Public School, Gali NO 111, B Block Sant Nya Benari
2. Type of Occupancy: Educational
3. Type of Case: New Case / Renewal
4. Details of previous NOC: Nil
5. Fire Safety directives letter No: Director of Edu dtd 01/03/2011
6. Date of inspection: 27/06/2013
7. Name of the Inspecting Officers: DO (NW)
8. Name and designation of officers from the building side: SP Birender Rautela
9. Year of Construction: 2009 (G+1) & one finished room on terrace not for school purpose, found vacant (affidavit enclosed)
10. Applicant's letter No.: nil dtd. 20/3/13

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	m/R
	• Gate width	-	-	-
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	2	m/R
	• Basements	-	-	-
	b. Width of staircases			
	• Upper Floors	1.5m	Exit step in 27 to 30 cms. upper steps are 90-95 cms in both the stcs.	m/R
	• Basements	-	-	-
	c. Protection of exits			
	• Fire check door		N/R	
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	1m	1m with door fittings less than 45 students	m/R
3	Compartmentation.			
	• Fire check door		N/R	
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			

5	Fire Extinguishers	<ul style="list-style-type: none"> Total numbers Types IS marking 	04 ISI marked	04 ABC P	m/r m/r m/r
6	First-Aid Hose Reels.	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm	N/R	
7	Automatic fire detection and alarming system.	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 		N/R	
8	MOEFA				
9	Public Address System.			N/R	
10	Automatic Sprinkler System.	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 		N/R	
11	Internal Hydrants	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 		N/R	
12	Yard Hydrants.	<ul style="list-style-type: none"> Total number of hydrants Hose Box 			
13	Pumping Arrangements.	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump 		N/R	

14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		N/R	
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		N/R	
17	Standby power supply			
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 		N/R	
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		N/R	
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The first step of both the staircases is 77 to 80 cms. Upper steps are 90 to 94 cms. Premises meets the requirement of 9+1 step bldg.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....



Signature of the Inspecting Officer

Name

Designation

Handwritten signature and initials

Handwritten text: C/o, Contact 211

Signature of the Inspecting Officer

Name

Designation

Handwritten signature and date: 28/6/13