

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

E-mail:- [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)

Fax:- 011-23412593

No. F.6/DFS/MS/GH/2013/52/655

Dated: 01/08/2013

FIRE SAFETY CERTIFICATE

Certified that the Guest House **Excel Inn** located at E-16, Naraina Vihar, New Delhi-110028 comprised of Basement, Stilt, Ground floor plus three upper floors, basement is vacant/storage, stilt floor as parking, ground floor used as reception, office & 04 guest rooms, first, second & third floor each having 06 guest rooms and one store respectively (Total 22 guest rooms), A kitchen for staff in temporary shed on terrace owned/occupied by Sh. Kundan Dass Rai S/o Late Sh. Atma Ram. The guest house building was inspected by the officer concerned of this department on 27.07.2013 in the presence of Sh. Kundan Dass Rai (Owner) and found that the owner have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class residential w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....01/08/2013.....at New Delhi.

  
(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:- 011-23414333

Copy to:-

1. The Addl. Commissioner of Police (Lic.)  
1<sup>st</sup> floor, P.S., Defence Colony, New Delhi.  
(Re. No.31877-81/Addl. C.P./Lic.(H), Dated 28.06.2013)
2. Sh. Kunda Dass Rai (Owner)  
Guest House Excel Inn,  
E-16, Naraina Vihar, New Delhi-110028.



Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provisions of the Building Bye Laws, 1983.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N/1.

Basement, Stilt, Ground Floor plus three Upper Floors.

## INSPECTION REPORT

1. Name & address of the building : G.H Excel Inn, E-16, Naraina Vihar, N.D.
2. Type of Occupancy : Residential (Guest House)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. \_\_\_\_\_ Date \_\_\_\_\_
5. Fire Safety directives letter No. : \_\_\_\_\_
6. Date of inspection : 27.07.2013
7. Name of Inspecting Officer : A.D.O P.S. Dahiya
8. Name and designation of officers  
From the building side : Sh. Kundan Dass Rai (Owner)
9. Year of Construction : 2009-10
10. Applicant's letter No. : 31877-81/ Addl. C.P/Lic.(H) dated 28.06.13

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	18 mtr	MR
	• Gate width	-	265cm, 375cm	MR
	• Width of internal road	-	-	-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	One	One	MR, Bldg. Plan sanctioned on 26.06.2008
	• Basements	Two	Two	MR
	b. Width of staircases			
	• Upper Floor	-	125cm	MR, Bldg. Plan sanctioned on 26.06.2008
	• Basements	-	150cm, 125cm	MR
	c. Protection of exits			
	• Fire check door	-	-	-
	• pressurization	-	-	-
	d. No. of continuous staircases to terrace	-	One	-
	e. Width of Corridor	-	210cm, 100cm	-
	f. Door Size	-	86cm x 205cm	-
3.	Compartmentation			
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	Sealed	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4.	Smoke Management System			
	• Basements	30 a/c per hour	Exhaust Fans are provided	MR
	• Upper floors		Natural Ventilation	MR

N/2

12 a/c per hour

5.	Fire Extinguishers		-	-
	• Total numbers	Two at each floor	Provided	MR
	• Types	CO <sub>2</sub> , ABC	- do -	MR
	• IS marking	ISI marked	ISI Marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	-	-
	• Hooters' Location	-	D.G. Set of 62.5 kVA	-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-	-	-
10.	Automatic Sprinkler System			
	• Basement	-	Provided	MR, Area less than 200 sq. m
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	-	-	-
	• Number of hydrants per floor	-	-	-
	• Hose Box	-	-	-
12.	Yard Hydrants			
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-

N/3

E-16, Naraina Vihar,  
New Delhi.

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">450 LPM</p> <p style="text-align: center;">30m</p> <p style="text-align: center;">Required</p> <p style="text-align: center;">—</p>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">450 LPM</p> <p style="text-align: center;">30m</p> <p style="text-align: center;">Provided</p> <p style="text-align: center;">—</p>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">MR</p> <p style="text-align: center;">MR</p> <p style="text-align: center;">MR</p> <p style="text-align: center;">—</p>
<b>14.</b>	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">5000 Ltr</p> <p style="text-align: center;">Required</p>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">10000 Ltr</p> <p style="text-align: center;">Provided</p>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">MR</p> <p style="text-align: center;">MR</p>
<b>15.</b>	<b>Exit Signage.</b>			
<b>16.</b>	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">Required</p> <p style="text-align: center;">-do-</p>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">Provided</p> <p style="text-align: center;">-do-</p> <p style="text-align: center;">-do-</p>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">MR</p> <p style="text-align: center;">MR</p> <p style="text-align: center;">MR</p>
<b>17.</b>	<b>Standby power supply</b>			
<b>18.</b>	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p>
<b>19.</b>	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">Required</p> <p style="text-align: center;">—</p>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">Provided</p> <p style="text-align: center;">—</p>	<p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p> <p style="text-align: center;">MR</p> <p style="text-align: center;">—</p>
<b>20.</b>	<b>Special Fire Protection System for Protection of special Risks, if any:</b>			
		<p style="text-align: center;">—</p>	<p style="text-align: center;">—</p>	<p style="text-align: center;">—</p>

N/4.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note:- The Guest house building is comprised of basement, Stilt, Ground floor plus three upper floors. The basement is served by two staircases having area 187 sq. m as per building plan sanctioned vide dated 26.06.2008. The upper floors are served by a single stair case having width 125 cms. The basement used as storage/vacant, stilt as parking, Ground floor having reception, Office & 04 Guest rooms, first, second & third floor each having 06 Guest rooms & 01 store respectively, A Kitchen for staff in temporary shed on terrace (Total 22 Guest rooms). The building plan sanctioned vide letter No. 176/B/RB2/2008/141 dated 26.06.2008. The height of the building is 14.70mtr as per the affidavit submitted by the owner.

Signature of Inspecting Officer

Name

Designation

*Malya*  
24/11/13  
P.S. Dahiya

Asstt. Divisional Officer

Signature of Inspecting Officer

Name

Designation