

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

Fax: 011-23412593, Email :- cfohq.dfire@nic.in, Ph:- 011-23414333

NO. F6/DFS/MS/EH/2013/SZ/ 656

DATED: 01/08/13

FIRE SAFETY CERTIFICATE

Certified that the M/s Gola Sizzler at Shop No. F-05, 1st Floor HL Square, Plot No. 6, Sector-5, Dwarka, New Delhi-110075 is running at 1st floor of the building comprised of ground, plus three upper floors was granted NOC by this department vide letter no. F6/DFS/MS/EH/2010/2013 Dated 08.07.2010. The premises was re-inspected by officers concerned of fire service on 27.07.2013 in the presence of Mr. Mohit Nanda (Partner) of the restaurant and that the building is fit for occupancy class D "Assembly building (Restaurant)" with effect from...01/08/13... for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to condition as mentioned below..

Issued on01/08/13..... at New Delhi by



(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

all
OK

Copy To:-

1. The Asst. comm.(restaurant Branch) Govt. of NCT of Delhi, Office of the commissioner of excise Entt. & Tax Dept. L& N Block I.P Estate. Vikas Bhawan New Delhi 110002.
2. The Manager M/s Gola Sizzlar Shop No. F-05, 1st Floor HL Square, Plot No. 6, Sector-5, Dwarka, New Delhi-110075.

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & address of the building	M/S Gola Sizzler Shop No. F-05, 1st Floor, HL Square Plot No. 6 Sector 5 Dwarka New Delhi-110075		
2	Type of Occupancy	Assembly "D" Resturant		
3	Type of case	Renewal		
4	Details of previous NOC	No. F-6/DFS/MS/EH/2010/2013 dated 8/7/10		
5	Fire safety directives letter No	Nil		
6	Date of inspection	27/7/13		
7	Name of the inspecting Officers :	ADO S.P Bhardwaj (Dwarka)		
8	Name and designation of officers from the building side	Mr. Mohit Nanda		
9	Year of construction	2007	Resurent Runinig at 1st Floor	
		Nil Dt 17.7.13	Ground + 3 upper Floors	
10	Applicant's letter No.			
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Old Case /NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	10mtrs	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	One	One provided	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	Old Case	1.5 Mtrs	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	One	
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Required	1.5 , 1.00 Mtr Provided	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour	N/A	N/A
		12 a/c per hour		
	upper floors		Exhust Fans provided	MR

5	Fire Extinguishers		4 Nos	MR
	total numbers		ABC, Co2,	MR
	Types		Yes	MR
	ISI marking	ISI		
6	First-Aid Hose Reels.			
	total numbers on each floor	1 No.	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	Provided	N/A
	location of Main Panel	N/A	Provided	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	Battery	MR
	hooter's location	N/A	Near Gate	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 MM	Provided	MR
	Number of Hydrants per floor	One	Provided	MR
	hose Box	Required	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level/			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	Old Case	450 LPM, 180 LPM	MR
	b. head of the pump	Old Case	40 Mtrs	MR
	c. Power supply	Required	Provided	MR
d. Auto starting of pump	Required	Provided	MR	
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	Old Case	5000 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/5

17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: N/A			

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule, the grant of Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/

Accordingly DFA is put up for your approval and signature please.

Signature of the Inspecting Officer

Name

S.P Bhardwaj

Designation

ADO (DWARKA)

S.P Bhardwaj
27/12/13