

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/OFS/MS/School/2013/W2/662

Dated: 02/08/2013

FIRE SAFETY CERTIFICATE

Certified that the Govt. Boys Middle School, E-Block, Kamla Nagar, Delhi is comprised of Ground + One owned/occupied by Govt. Boys Middle School at First Floor and MCD School have on Ground Floor have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 17/07/2013 in the presence of Sh. Kuldeep Kumar and that the building / premises is fit for occupancy of Educational building with effect from 02/08/2013 for a period of three years, subject to following conditions.

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building bye laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 02.08.2013 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in



Copy to:

1. The Principal, Govt. Boys Middle School, E-Block, Kamla Nagar, Delhi.
2. The Director of Education, Old Secretariate, Delhi-110054

INSPECTION REPORT

1. Name & address of the building Govt. Boys Middle School, E-Block, Karam Nagar,
 2. Type of Occupancy Educational (FD. 1207027) Delhi-7.
 3. Type of Case New Case/ ~~Renewal~~
 4. Details of previous NOC : Letter No. NIL Dated: _____
 5. Fire Safety directives letter No Circular, Director of Educn. 1/3/2011
 6. Date of inspection 17-7-2013
 7. Name of the Inspecting Officers : ADO - SHYAM LAL
 8. Name and designation of officers sh. Kuldeep Kumar
 from the building side
 9. Year of Construction 1962, (Ground + / upper floor, Sch)
 10. Applicant's letter No. - at 1st floor, G. Floor MED school.
GBMS/KN/1654/56 dated 6-7-2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	<u>Circular, Dir. of Educn. 1/3/2011</u> Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessible</u>	<u>6 m</u>	<u>MIR</u>
	• Gate width	<u>—</u>	<u>3.5 m x 2</u>	<u>MIR</u>
	• Width of internal road	<u>—</u>	<u>N/A</u>	<u>N/A</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>2</u>	<u>2 -</u>	<u>MIR</u>
	• Upper Floors	<u>2</u>	<u>2 -</u>	<u>MIR</u>
	• Basements	<u>NIL</u>	<u>NIL</u>	<u>NIL</u>
	b. Width of staircases			
	• Upper Floors	<u>1.5 m</u>	<u>1.6 m & 1.25 m</u>	<u>MIR</u>
	• Basements	<u>NIL</u>	<u>NIL</u>	<u>NIL</u>
	c. Protection of exits			
	• Fire check door		<u>NIR</u>	
	• Pressurization		<u> </u>	
	e. No. of continuous staircases to terrace		<u>NIR</u>	
	g. Width of Corridor	<u>R</u>	<u>2.45 m</u>	
	h. Door Size	<u>1 m</u>	<u>1.05 m</u> <u>(one door)</u>	<u>MIR</u>
3	Compartmentation.			
	• Fire check door		<u>NIR</u>	
	• Sealing of electrical shafts		<u> </u>	
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	30 a/c per hour	<u>NIR</u>	
	• Upper floors	12 a/c per hour	<u> </u>	

less than us students in each class.

31 N

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	<p>5</p> <p>ABC/CO2(25kg)</p> <p>ISI marked</p>	<p>provided</p> <p>provided</p> <p>provided</p>	<p>MIR</p> <p>MIR</p> <p>MIR</p>
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	<p>30 m</p> <p>5 mm</p>	<p>NIR</p>	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 		<p>NIR</p>	
8	MOEFA			
			<p>NIR</p>	
9	Public Address System.			
			<p>NIR</p>	
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 		<p>NIR</p>	
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 		<p>NIR</p>	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 		<p>NIR</p>	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 		<p>NIR</p>	

4/11

14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 		NIR	
15	Exit Signage.		NIR	
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 		NIA	
17	Standby power supply		NIR	
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 		NIR	
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 		NIR	
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	NIL	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

DOJ
NW

Signature of the Inspecting Officer

Name

Designation

SHYAM LAL

Asstt. Dirn. Officer

17/7/2013

The file may be numbered please.

Submitted by
17/7/2013

17/7/13