

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/2013/W2/652 Dated: 01/08/2013

**FIRE SAFETY CERTIFICATE**

Certified that the **Kendriya Vidyalaya, AN-Block, Shalimar Bagh, Delhi**, is comprised of Ground + upper three floors owned/occupied by **Kendriya Vidyalaya, AN-Block, Shalimar Bagh**, have complied with the fire prevention and fire requirements in accordance with, the **Circular No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01/03/2011** issued by Director of Education/NBC-IV and verified by the officer concerned of Fire Service on **10/07/2013** in the presence of **Smt. Sushma Chaudhary (Principal)** and that the building/premises is fit for occupancy of **Educational** building with effect from 01/08/2013 for a period of **three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire service rules, 2010.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the /construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on 01/08/13 at New Delhi by



(Santokh Singh)

Chief Fire Officer

Delhi Fire Service

Ph : 011-23414250

E-mail : cfowz.dlfire@nic.in

*ole*

Copy to:

1. The Principal, Kendriya Vidyalaya, AN-Block, Shalimar Bagh, Delhi
2. ~~The Director of Education, Old Secretariat, Delhi~~  
*Kendriya Vidyalaya Sangathan, Delhi Region, JNU Campus, New Mehrauli Road, Delhi - 110067.*

Re inspection to verify shortcomings.

**RE-INSPECTION REPORT**

1. Name & address of the building : Kendriya Vidyalaya, AN-Block, Shalimar Bldg.
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No.                      Dated:
5. Fire Safety directives letter No : D.O.E Circular dt. 01/03/2011
6. Date of inspection : 10/07/2013
7. Name of the Inspecting Officers : ADO(wP), S.K. Dua
8. Name and designation of officers from the building side : Smt. Sushma Chaudhary, Principal
9. Year of Construction : 1988
10. Applicant's letter No. : F.S-12/KV-SB/2010-11/13Bldg/162 dt. 05/Jul/13

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	Two	Four	MR
	• Upper Floors	— n —	— n —	MR
	• Basements			
	b. Width of staircases	1.5 mtr	1) 1.42 mtr 2) 1.42 mtr 3) 1.37 m 4) 1.37 mtr	MR
	• Upper Floors			
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	Two	Provided	MR
	g. Width of Corridor	—	—	—
	h. Door Size	1.0 mtr	1.0 mtr	MR

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>			N/A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour		N/A
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	18 Nos. ISI marked	20 CO <sub>2</sub> + 30 ABC-5kg. Yes Yes	MR MR MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	One at each floor. 30 m 5 mm	Two at each floor Yes Yes	MR MR MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>			N/A
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>	Repd.	Bonded	MR
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>			N/A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	NA	NA	NA

	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>		N/A	
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>		N/A	
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>		N/A	
		one pump of 450 LPM	Two pumps of 450 LPM	MR
		450 LPM	yes	MR
		40 m	40 M	MR
		-	-	-
		-	-	-
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NR	150000 Lts.	-
		-	-	-
		-	-	-
		-	-	-
		10,000 Lts.	20,000 Lts.	MR
15	<b>Exit Signage.</b>	Reqd.	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> </ul>		N/A	

	<ul style="list-style-type: none"> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>			
17	<b>Standby power supply</b>			
18	<b>Refuge Area.</b>			
	➤ Total Area			
	➤ Location			
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....

Signature of the Inspecting Officer

Name S. K. DUG

Designation ADDO (WP)

Signature of the Inspecting Officer

Name

Designation