

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001
Fax : 23412593, E-mail: cfohq.dlfire@nic.in Tel :- 011-23414333

No.F6/DFS/MS/EH/2013/NDZ/650

Dated : 30/07/13

FIRE SAFETY CERTIFICATE

Certified that the Restaurant in the name and style of KFC (A Unit of Yam Restaurant (India) Pvt. Ltd.) at ground floor and mezzanine floor located at 6, Scindia House, Connaught Place, New Delhi - 110001 comprised of ground, mezzanine plus two upper floor was granted NOC by this department vide letter No. F6/DFS/MS/EH/2009/2509 dated 12-08-2009. The premises was re-inspected by the officer concerned of this department on 21-07-2013 in the presence of Mr. Harvinder Verma (manager) and found that the said restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy with effect from 30/07/2013 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire service subject to conditions printed overleaf.

Issued 30/07/13 at New Delhi by.



(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

Copy to :

1. KFC (A Unit of Yam Restaurant (India) Pvt. Ltd.), 6, Scindia House, Connaught Place, New Delhi - 110001
2. Medical officer of Health, Health Department, Palika Kendra, Sansad Marg, New Delhi-110001.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

Recd at New Delhi


30/7/13

INSPECTION REPORT

1. Name & address of the building : KFC (A Unit of Yam Restaurant (India) Pvt. Ltd.) located at 6, Scindia House, Connaught Place, New Delhi – 110001
2. Type of Occupancy : Eating House
3. Type of Case : Renewal *(G+MEZ+Two)*
4. Details of previous NOC : Letter No. F6/DFS/MS/EH/2009/2509 dated 12-08-2009
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 21-07-2013
7. Name of the Inspecting Officer : Sh. D.S.YADAV (D.O.)
8. Name and designation of Officer
from the building side : Mr. Harvinder Verma (Manager)
9. Year of Construction : 2009 Starting Year
10. Applicant's letter No. : Nil dated 10-07-2013

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR (Old Case)
1.	Access of building			
	• Road width	accessible	More then 6 mtrs.	MR
	• Gate width	N/A	Directly accessible from main road	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01	02	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	Required	80cms and 110 cms	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	N/A	N/A
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	30 a/c per hour	N/A	MR
	• Upper floors	12 a/c per hour	Exhaust Fan	MR

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	10	10	MR
	<ul style="list-style-type: none"> Types 	Co2 & A.B.C. type.	MR
	<ul style="list-style-type: none"> IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	01	01	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 M	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooters' Location 	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System/Intercom	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper Floor (Mezzanine floor) 	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Number of hydrants per floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Head of main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Jockey pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Jockey pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Standby Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Standby Pump Head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> auto Staring/Manual stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> Discharge of pump 	450 LPM & 180 LPM	Provided	MR
	<ul style="list-style-type: none"> Head of the pump 	40 Mtrs. Each	Provided	MR
	<ul style="list-style-type: none"> Power supply 	Required	Provided	MR
	<ul style="list-style-type: none"> Auto starting of pump 	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Draw of connection 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	5000 ltrs.	5000 ltrs	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of lift lobby 	N/A	N/A	N/A

N/4

KFC (A Unit of Yam Restaurant (India) Pvt. Ltd.), 6, Scindia House, Connaught Place, New Delhi - 110001

	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided (DG set)	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	One co2 type fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer

Name
Designation

Signature of the Inspecting Officer

Name *Prabon vir Singh yadav*
Designation *Divisional officer (central)*

OFFICE