

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No.F.6/DFS/MS/School/2013/ 52/668

Dated: 06/08/13

FIRE SAFETY CERTIFICATE


Certified that the **A.V.S Model School** located at D-106 & 107, Sita Puri, 30 ft. Road, Near Pankha Road, New Delhi-110045 comprised of ground floor plus one upper floor, having total 14 rooms (Including Class Rooms, Office, Staff Room & Store etc.) was issued NOC by this department vide letter No.F.6/DFS/MS/2008/299 dated 06.02.2008. The School building was re- inspected by the officer concerned of this department on 26.07.2013 in the presence of Sh. K.R. Dalal (Manager) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on.....06/08/13.....at New Delhi.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Manager,
A.V.S. Model School,
D-106 & 107, Sita Puri, 30 ft. Road,
Near Pankha Road, New Delhi-110045.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi – 110054.



Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: A.V.S Model School, D-106, Sitapura, 30th Road ND-45
2. Type of Occupancy : Educational
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F.G/DFS/MS/2008/299 Dated 06/02/08
5. Fire Safety directives letter No : Nil
6. Date of inspection : 26/07/2013
7. Name of Inspecting Officer : ADO Sandeep Duggal
8. Name and designation of officers
From the building side : Mr K.R. Dalal
9. Year of Construction : _____
10. Applicant's letter No. : AVS/13/1138 dated 06/06/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	08m x 5m	MR
	• Gate width	—	230cms x 195cms	—
	• Width of internal road	—	—	—
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	—	—	No Basement
	b. Width of staircases			
	• Upper Floor	—	13 x 1m	MR
	• Basements	—	—	No Basement
	c. Protection of exits			
	• Fire check door	—	—	—
	• pressurization	—	—	—
	d. No. of continuous staircases to terrace	—	one	—
	e. Width of Corridor	—	180cms.	—
	f. Door Size	—	90cms	MR (Being old case)
3.	Compartmentation			
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4.	Smoke Management System			
	• Basements	30 a/c per hour	—	—
	• Upper floors	—	natural ventilation	MR

N/S

A.V.S Model School
D-106, Sitapuri, 30 feet Rd
ND-45

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
		—	220 Lpm	—
		—	40 m	—
		—	—	—
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	2500 ltr	—
15.	Exit Signage.	—	—	—
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	No Lift
		—	—	do
		—	—	do
		—	—	do
		—	—	do
17.	Standby power supply	—	—	do
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
		—	—	—
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
20.	Special Fire Protection System for Protection of special Risks, if any:	—	—	—

N/6

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note :- In each class students less than 45 as per letter submitted by School management, dated 26/7/13 hence double door is not required in rooms.

Sandeep
3/5/7/13
Signature of Inspecting Officer

Name Sandeep Duggal

Designation Asstt Divisional Officer

Signature of Inspecting Officer

Name

Designation

FIRE