

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

E-mail:- [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)

Fax:- 011-23412593

No. F.6/DFS/MS/School/2013/ 02/669

Dated: 06/08/13

FIRE SAFETY CERTIFICATE

Certified that the **Guru Nanak Public School** located at G-8 Area, Opp. Sports Complex, Near Swarag Ashram, Rajouri Garden, New Delhi-110064 comprised of Ground floor plus two upper floors, having total 77 rooms (Including Class Rooms, Offices, Sci. Lab, Comp. Lab, Art Room, Medical Room, Judo Room, Music Room & Resource Room etc.) was issued NOC by this department vide letter No.F.6/DFS/MS/2008/559 dated 27.02.2008. The School building was re- inspected by the officer concerned of this department on 25.07.2013 in the presence of Sh. Arvinder Singh (Incharge) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....at New Delhi.



(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:- 011-23414333

Copy to:-

1. The Principal,  
Guru Nanak Public School, G-8 Area,  
Opp. Sports Complex, Near Swarag Ashram,  
Rajouri Garden, New Delhi-110064.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi - 110 054

ole  
Day

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N/S

Ground floor + Two

INSPECTION REPORT

1. Name & address of the building : Guru Nanak Public School, Gr-8, opp Sports Complex, Near Swarg Ashram, Rajouri Garden, ND-64
2. Type of Occupancy : Educational
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. P6/DFS/MS/2008/559 Date 27/2/2008
5. Fire Safety directives letter No : Nil
6. Date of inspection : 25-07-2013
7. Name of Inspecting Officer : ADO Sandeep Duggal
8. Name and designation of officers  
From the building side : Sh Arvinder Singh (Incharge)
9. Year of Construction : 1998.
10. Applicant's letter No. : Nil dated 03/7/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks
1.	Access to building <ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible	12 m 4.56 & 4.50 m	- M/R MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases <ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	—	04	M/R No Basement
	b. Width of staircases <ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	—	135, 145, 145 & 135 cms	MR (old case) No Basement
	c. Protection of exits <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• pressurization</li> </ul>	—	—	—
	d. No. of continuous staircases to terrace	—	02	MR
	e. Width of Corridor	—	235 cms	
	f. Door Size	—	94 cms (one)	MR (old case)
3.	Compartmentation <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	—	—	—
4.	Smoke Management System <ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour	—	No Basement
		—	Natural Ventilation.	—



		12 a/c per hour	—	—	—
5.	Fire Extinguishers				
	• Total numbers	20 ABC & CO <sub>2</sub> ISI marked	Provided	MR	
	• Types		— do —	MR	
	• IS marking		ISI marked	MR	
6.	First-Aid Hose Reels				
	• Total numbers on each floor	Two	Provided	MR	
	• Length of hose reel hose	30 m	— do —	MR	
	• Nozzle diameter	5 mm	— do —	MR	
7.	Automatic fire detection and alarming system				
	• Type of detectors	—	—	—	
	• Location of Main Panel	—	—	—	
	• Location of Repeater Panel	—	—	—	
	• Alternate source of power	—	—	—	
	• Hooters' Location	—	—	—	
8.	MOEFA	—	—	—	
9.	Public Address System	—	Provided	—	
10.	Automatic Sprinkler System				
	• Basement	—	—	No Basement	
	• Upper Floor	—	—	—	
	• Sprinkler above false ceiling	—	—	—	
11.	Internal Hydrants				
	• Size of riser/down-comer	—	provided	—	
	• Number of hydrants per floor	—	— do —	—	
	• Hose Box	—	— do —	—	
12.	Yard Hydrants				
	• Total number of hydrants	—	—	—	
	• Hose Box	—	—	—	
13.	Pumping Arrangements				
	• Ground Level				
	➤ Discharge of main Pump	—	—	—	
	➤ Head of Main pump	—	—	—	
	➤ Number of main pumps	—	—	—	
	➤ Jockey Pump out put	—	—	—	
	➤ Jockey pump head	—	—	—	
	➤ Standby Pump out put	—	—	—	
	➤ Standby Pump Head	—	—	—	
	➤ Auto Starting/Manual stopping	—	—	—	

N/7

Guru Nanak Public School,  
 A-8, opp. Sports Complex, Near Swarg  
 Ashram, Rajouri Garden, ND-64

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	—	—	—
		450 lpm	360 lpm (each)	MR (Two pumps)
		30 m	46m, 26m	MR (Two pumps)
		—	—	—
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	—	—	—
		—	—	—
		—	Provided.	—
		—	—	—
		10,000 ltr	10000 lbs	MR
15.	<b>Exit Signage.</b>			
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	—	—	No lift
		—	—	do
		—	—	do
		—	—	do
		—	—	do
17.	<b>Standby power supply</b>	—	25 KVA DG set	MR
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	—	—	—
		—	—	—
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	—	—	—

N/B

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note :- In each class students are less than 45 as Undertaking given by the school management letter no GNPS/F4S/2013 dated 26/07/13, hence no requirement of double <sup>sec</sup> door.

Sandeep  
20/7/13

Signature of Inspecting Officer

Name

Sandeep Duggal

Designation

Asstt. Divisional officer

Signature of Inspecting Officer

Name

Designation

