

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

Fax:- 011-23412593

E-mail ID: cfohq.dlfire@nic.in

No F6/DFS/MS/School/2013/NO2/675

Dated: 07/08/13

FIRE SAFETY CERTIFICATE

Certified that the ST. Anthony's Girls Sr. Sec. School at Pahar Ganj – 110055 owned / occupied by ST. Anthony's Girls Sr. Sec. School building comprised of ground floor plus two upper floors have compiled with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01-03-2011 and verified by the officer concerned of Delhi Fire Service on 29-07-2013 in the presence of Ms Laura, Manager and that the building is fit for occupancy class B "Educational Building" with effect from 07/08/13 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions rule 38 of the Delhi Fire subject to the condition printed overleaf.

Issued on07/08/13..... at New Delhi by.



(Dr G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. The ST. Anthony's Girls Sr. Sec. School, Pahar Ganj – 110055.
2. The Director Education, Old Secretariat, Delhi – 110054.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : **Sr ANTHONY'S Girls Sr. Sec. School**
Punharganj

2. Type of Occupancy : **Educational G+2 Floor**

3. Type of Case : **Fresh**

4. Details of previous NOC : **NA**

Fire Safety directives Letter No. : **NA**

Date of inspection : **29/7/13**

Name of the Inspecting Officer : **M.K. Sharma (Assistant Divisional Officer)**

Name and designation of Officer
 from the building side : **Sister Laxman**

Year of Construction : **Old existing Bldg**

10. Applicant's letter No. : **S.A.G.S 112-13 Dt 6/6/13**

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site (PSS Area)	Remarks MR/NMR (P.S.S Area)
1.	Access of building			
	• Road width	NA	10 m	MR
	• Gate width	1.5 m	2 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	03	05	MR
	• Upper floors	03	05	MR
	• Basements	NA	NA	NA
	b. Width of staircases	m x to 1.5 m	1.5, 2.5, 1 m	MR
	• Upper floors	m x to 1.5 m	P	MR
	• Basements			
	c. Protection of exits			
	• Fire check door	NA		
	• Pressurization			
	d. No of continuous staircase to terrace	02	03	MR
	e. Width Of Corridor	1.5 m	2.9 m	MR
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke managements System			
	• Basements			

	• Upper floors	12 AEPH.	Natural	MR
5	Fire Extinguishers			
	• Total numbers	16	P	MR
	• Types	ABC, CO ₂	P	MR
	• IS marking	Yes	P	MR
6	First - Aid Hose Reels			
	• Total numbers on each floor	0 2	0 4	MR
	• Length of hose reel hose	30 m	P	MR
	• Nozzle diameter	05 mm	P	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NTA		
	• Location of Main Panel			
	• Location of Repeater Panel			
	• Alternate source of power			
	• Hooters' Location			
8	MOEFA	NR	NP	MR
9	Public Address System	Yes	P	MR
10	Automatic Sprinkler System			
	• Basements	NTA		
	• Upper Floor			
	• Sprinkler above false ceiling			
11	Internal Hydrants			
	• Size of riser/down-comer	150 mm	P	MR
	• Number of hydrants per floor	0 2	0 3	MR
	• Hose Box	0 3	0 3	MR
12	Yard Hydrants			
	• Total number of hydrants	NTA		
	• Hose Box			
13	Pumping Arrangements			
	○ Ground Level			
	• Discharge of main pump	220 LPM	450 LPM	MR
	• Head of main pump	30 m	P	MR
	• Number of main pumps			
	• Jockey pump out put			
	• Jockey pump head			
	• Standby Pump out put			
	• Standby Pump Head			
	• auto Starting/Manual stopping			
	• Pump House Access			
	○ Terrace level			
	• Discharge of pump			
	• Head of the pump			
	• Power supply			
	• Auto starting of pump			
14	Captive water Storage for fire fighting			
	• Under ground tank capacity	NR	50,000	MR

	<ul style="list-style-type: none"> • Draw of connection • Fire service inlet • Access to tank • Overhead Tank capacity 	NR	P	MR
		NA	NA	NA
		Yes	P	MR
		5000	P	MR
15	Exit Signage	Yes	P	MR
16	Provision of Lifts	NA		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of lift lobby • Communication in lift Car • Fireman's Grounding Switch • Lift Signage 	NA		
17	Standby power supply	NA	NA	NA
18	Refuge Area	NA		
	<ul style="list-style-type: none"> • Total area • Location 	NA		
19	Fire control room	NA		
	<ul style="list-style-type: none"> • Detector system panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	NA		
20	Special Fire Protection Systems for Protection of special Risks, if any;	Yes	CO2 ABC	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / ~~issue shortcoming as noted at serial numbers:~~.....

Signature of the Inspecting Officer

Name :- M.K. Sharma
Designation :- ADO (CC)

Signature of the Inspecting Officer

Name :-
Designation :-