

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2012/W2/684

Dated: 08/08/2013

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya, Nehru Vihar, Delhi is comprised of Ground + three Upper Floor & Ground Only owned/occupied by Sarvodaya Kenya Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education NBC Part IV and verified by the officer concerned of Fire Service on 20/07/2013 in the presence of Sh. Sushma J Toppa and that the building / premises is fit for occupancy of Educational building with effect from 08/08/2013 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building bye laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 08/08/13 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Sarvodaya Kanya Vidyalaya, Nehru Vihar, Delhi
2. The Director of Education, old Secretariate, Delhi.



INSPECTION REPORT

1. Name & address of the building: Sarvodaya Kanya Vidyalaya, Nehru Vihar, Delhi
2. Type of Occupancy: Educational (I.D. - 1207004)
3. Type of Case: New Case/ Renewal
4. Details of previous NOC : Letter No. NIL Dated: _____
5. Fire Safety directives letter No: Circular, Dir. of Edun. 1/3/2011
6. Date of inspection: 20-07-2013
7. Name of the Inspecting Officers: ADO - SHYAM LAL
8. Name and designation of officers from the building side: Smt. Sushma J. Tappa. (Principal)
9. Year of Construction: 1981, (Ground + 3 upper floor and Ground only)
10. Applicant's letter No. (one block) (Two block)

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Circular, Dir. of Edun. Requirement 1/3/2011 | Provided at site | Remarks MR/NMR |
|--------|---|--|-------------------------------------|-----------------------------------|
| 1 | Access to building | | | |
| | • Road width | Accessible | 9 m | M/R |
| | • Gate width | -ob- | 4.5 m | M/R |
| | • Width of internal road | -do- | 6 m | M/R |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 4 | 4 | M/R |
| | • Basements | 4 | 4 | M/R |
| | b. Width of staircases | NIL | NIL | NIL |
| | • Upper Floors | 1.5 m | 1.5 m (Two Nos) 1.33 m (Two Nos) | M/R |
| | • Basements | NIL | NIL | NIL |
| | c. Protection of exits | | | |
| | • Fire check door | | N/R | |
| | • Pressurization | | | |
| | e. No. of continuous staircases to terrace | R | 2 | M/R |
| | g. Width of Corridor | R | 2.65 m | M/R |
| | h. Door Size | 1 m | 1.07 m (two doors) | M/R |
| 3 | Compartmentation. | | | (more than 15 student each class) |
| | • Fire check door | | N/R | |
| | • Sealing of electrical shafts | | | |
| | • Fire Rating of shaft door | | | |
| | • Water Curtain | | | |
| | • Fire Dampers | | | |
| 4 | Smoke Management System. | | | |
| | • Basements | 30 a/c per hour | N/R | |
| | • Upper floors | 12 a/c per hour | | |

3/ N

| | | | | |
|----|---|------------|------------|-----|
| 14 | Captive Water Storage for fire fighting. | | | |
| | <ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity | NIR | 50000 Lts. | NIR |
| | | | | |
| | | | | |
| | | 10000 Lts. | 15000 Lts. | MIR |
| 15 | Exit Signage. | R | provided | MIR |
| 16 | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage | | NIA | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| 17 | Standby power supply | | NIR | |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | | NIA | |
| | ➤ Location | | | |
| 19 | Fire Control Room | | | |
| | <ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans | | NIR | |
| | | | | |
| | | | | |
| | | | | |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | - | - Nil - | - |



The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer
 Name D.P. NW
 Designation
 Defto (w2)
 22/7/13

Signature of the Inspecting Officer
 Name (SHYAM LAL)
 Designation Assstt. Dirn. officer