

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. FG/DF-S/MS/School/2013/W2/683

Dated: 08/08/2013

FIRE SAFETY CERTIFICATE

Certified that the Yadavendra Public School, B-2097, Sant Nagar, Burari, Delhi-110084 is comprised of Ground + One upper floor having School on G.F only and residence at first floor owned/occupied by Yadavendra Edmn. Society complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 10/07/2013 in the presence of Ms. Jyoti and that the building / premises is fit for occupancy of Educational building with effect from 08/08/13 2013 for a period of three years, subject to following conditions.

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building bye laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 08/08/13 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Yadavendra Public School, B-2097, Sant Nagar, Burari, Delhi-110084.
2. The Addl. Director of Education, North MCD, Civic Centre New Delhi.

INSPECTION REPORT

1. Name & address of the building: Yadvendra Public School, B-2097, Sant Nagar, Binsari, Delhi.
2. Type of Occupancy: Educational.
3. Type of Case: New Case/ Renewal
4. Details of previous NOC: Letter No. N/C Dated: _____
5. Fire Safety directives letter No: Circular, Dir. of Edun. 1/3/2011
6. Date of inspection: 10-7-2013
7. Name of the Inspecting Officers: ADO - A. SHYAM LAL
8. Name and designation of officers from the building side: Ms. Jayali
9. Year of Construction: 2008, (School at Ground floor only & - first floor is residence.
10. Applicant's letter No.: 27 dated 8/6/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Provided at site	Remarks MR/NMR
1	Access to building		
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p><u>Circular, Dir. of Edun. Requirement 1/3/2011</u></p> <p>Accessible 6 m -do- 2.5m x 2 N/A N/A N/A</p>	<p>M/R M/R N/A</p>
2	Number, Width, Type & Arrangement of Exits		
	<ul style="list-style-type: none"> a. Number of staircases <ul style="list-style-type: none"> • Upper Floors • Basements b. Width of staircases <ul style="list-style-type: none"> • Upper Floors • Basements c. Protection of exits <ul style="list-style-type: none"> • Fire check door • Pressurization e. No. of continuous staircases to terrace g. Width of Corridor h. Door Size 	<p>N/A</p> <p>1 m</p>	<p>N/A</p> <p>1 m (one door) M/R less than 45 students</p>
3	Compartmentation.		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>N/A</p>	<p>N/A</p>
4	Smoke Management System.		
	<ul style="list-style-type: none"> • Basements • Upper floors 	<p>30 a/c per hour 12 a/c per hour</p>	<p>N/A 1</p>

N-2

5	Fire Extinguishers			
	• Total numbers	4	Provided	mjr
	• Types	ABC/CO2 (3.5kg)	Provided	mjr
	• IS marking	ISI marked	Provided	mjr
6	First-Aid Hose Reels.			
	• Total numbers on each floor		NIR	
	• Length of hose reel hose	30 m		
	• Nozzle diameter	5 mm		
7	Automatic fire detection and alarming system.			
	• Type of detectors		NIR	
	• Location of Main Panel			
	• Location of Repeater Panel			
	• Alternate source of power			
	• Hooters' Location			
8	MOEFA		NIR	
9	Public Address System.		NIR	
10	Automatic Sprinkler System.			
	• Basement		NIR	
	• Upper Floor			
	• Sprinkler above false ceiling			
11	Internal Hydrants			
	• Size of riser/down-comer		NIR	
	• Number of hydrants per floor			
	• Hose Box			
12	Yard Hydrants..			
	• Total number of hydrants		NIR	
	• Hose Box			
13	Pumping Arrangements.			
	• Ground Level		NIR	
	➤ Discharge of main Pump			
	➤ Head of Main pump			
	➤ Number of main pumps			
	➤ Jockey Pump out put			
	➤ Jockey pump head			
	➤ Standby Pump out put			
	➤ Standby Pump Head			
	➤ Auto Starting/ Manual stopping			
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump			
	➤ Head of the pump			
	➤ Power Supply			
➤ Auto Starting of pump				

14	Captive Water Storage for fire fighting.		
	• Underground tank capacity		NIR
	➤ Draw-off connection		
	➤ Fire service inlet		
	➤ Access to tank		
	• Overhead Tank capacity		
15	Exit Signage.		
16	Provision of Lifts.		
	• Pressurization of Lift Shaft		N/A
	• Pressurization of Lift lobby		
	• Communication In lift Car		
	• Fireman's Grounding Switch		
	• Lift Signage		
17	Standby power supply		
18	Refuge Area.		
	➤ Total Area		N/A
	➤ Location		
19	Fire Control Room		
	• Detector System Panel		NIR
	• Flow Switch Panel		
	• PA System Panel		
	• Batter backup		
	• Building Floor Plans		
20	Special Fire Protection Systems for Protection of special Risks, if any:		
		—	Nil

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

D.O/NW

Name

Gujh
17/7/13

Designation

Signature of the Inspecting Officer

Shyam Lal
12/7/2013

Name

(SHYAM LAL)

Designation

Asstt. Divn officer