

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No: F.6/DFS/MS/School/2013/ 52/698

Dated: 13/08/13

FIRE SAFETY CERTIFICATE

Certified that the building of **M.C. Primary Girls Partibha School**, Jharoda Kalan, New Delhi -110072 comprised of ground floor plus one upper floor, having total 19 rooms (Including Class Rooms, Office, Comp. Room, Sci. Lab, Sports Room, Store & Hall etc.) owned/occupied by MCD was inspected by the officer concerned of this department on 03.08.2013 in the presence of Smt. Shakuntla Rathi (Principal) and found that the M.C.D have complied with the fire prevention and fire safety requirements in accordance with the Circular No- F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on13/08/13.....at New Delhi



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to: -

1. The Principal,
M.C. Primary Girls Partibha School,
Jharoda Kalan, New Delhi-110072.
2. Director of Education,
South Delhi Municipal Corporation
23rd floor, Dr. S.P.M Civic Centre,
Minto Road, New Delhi-110002.

alc
Caf

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

N/B

G+1

INSPECTION REPORT

1. Name & address of the building: M.C. Primary Girls Partibha School, Jhasoda Kalan, NP-72
2. Type of Occupancy : Educational
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. — Dated —
5. Fire Safety directives letter No : —
6. Date of inspection : 03/08/2013
7. Name of Inspecting Officer : ADO Sandeep Duggal.
8. Name and designation of officers
From the building side : Mrs Shakuntla Rathi (Principal)
9. Year of Construction : Before 2011
10. Applicant's letter No. : Nil dated 04-05-2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	More than 10 mtr	MR
	• Gate width	—	3:35mtr / 148cms	MR
	• Width of internal road	—	—	—
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	01	MR
	• Basements	—	—	No Basement
	b. Width of staircases			
	• Upper Floor	150 cms	155 cms	MR
	• Basements	—	—	No Basement
	c. Protection of exits			
	• Fire check door	—	—	—
	• pressurization	—	—	—
	d. No. of continuous staircases to terrace	—	one	—
	e. Width of Corridor	—	220 cms	—
	f. Door Size	0.2m	110 cms	MR
3.	Compartmentation			
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4.	Smoke Management System			
	• Basements	30 a/c per hour	—	—
	• Upper floors	—	Natural Ventilation	MR

2/5

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
15.	Exit Signage.	—	—	—
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	—
17.	Standby power supply	—	—	—
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
20.	Special Fire Protection System for Protection of special Risks, if any:	—	—	—

N/6

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note :- The School building is comprised of Ground floor plus one upper floor.
The each class have less than 45 students as per the letter given by the principal dated 03/08/13. FSC is recommended please.



Sandeep
06/8/13

Signature of Inspecting Officer

Name Sandeep Duggal

Designation Asstt. Divisional officer.

Signature of Inspecting Officer

Name

Designation