

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/2013/ 695

Dated: 13/08/13

FIRE SAFETY CERTIFICATE

Certified that the **Satya Service Station** located at L-Block, Hari Nagar, Jail Road, New Delhi-110064 comprised of ground floor plus one upper floor but the service station is running at ground floor only owned/occupied by Major Jai Gopal Srivastava. The premises was inspected by the officer concerned of this department on 26.07.2013 in the presence of Sh. M.K. Sahib (Works Manager) and found that the said service station have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group J Hazardous Building w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....13/08/13..... at New Delhi.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. Sh. Major Jai Gopal Srivastava
Satya Service Station, L-Block,
Hari Nagar, Jail Road, New Delhi-110064.

all
Oxy

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

Petrol Pump

INSPECTION REPORT

1. Name & address of the building : Satya Service Station, L Block, Hazi Nagar, Group-J, Hazardous Building NO-64
2. Type of Occupancy : Group-J, Hazardous Building
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. — Date —
5. Fire Safety directives letter No : Nil
6. Date of inspection : 26/07/2013
7. Name of Inspecting Officer : ADO Sandeep Duggal
8. Name and designation of officers
From the building side : Mr M.K. Sahub (works Manager)
9. Year of Construction : 1978
10. Applicant's letter No. : SSS/CF/2013-14/01 dated 11/07/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p align="center">Accessible</p> <p align="center">—</p>	<p align="center">10mts (Two way) each.</p> <p align="center">—</p>	<p align="center">MR</p> <p align="center">—</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p align="center">—</p> <p align="center">—</p>	<p align="center">—</p> <p align="center">—</p>	<p align="center">—</p> <p align="center">NO Basement</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<p align="center">—</p> <p align="center">—</p>	<p align="center">—</p> <p align="center">—</p>	<p align="center">—</p> <p align="center">NO Basement</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • pressurization 	<p align="center">—</p> <p align="center">—</p>	<p align="center">—</p> <p align="center">—</p>	<p align="center">—</p> <p align="center">—</p>
	d. No. of continuous staircases to terrace			
		—	—	—
	e. Width of Corridor	—	—	—
	f. Door Size	—	1mts, 1mts	—
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p align="center">—</p> <p align="center">—</p> <p align="center">—</p> <p align="center">—</p> <p align="center">—</p>	<p align="center">—</p> <p align="center">—</p> <p align="center">—</p> <p align="center">—</p> <p align="center">—</p>	<p align="center">—</p> <p align="center">—</p> <p align="center">—</p> <p align="center">—</p> <p align="center">—</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<p align="center">30 a/c per hour</p> <p align="center">—</p>	<p align="center">—</p> <p align="center">—</p>	<p align="center">—</p> <p align="center">—</p>

		12 a/c per hour	—	—
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	12 No's PCP, ABC, CO2 ISI marked	Provided — do — ISI marked	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	— 30 m 5 mm	— — —	— — —
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	— — — — —	— — — — —	— — — — —
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	— — —	— — —	No Basement — —
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	— — —	— — —	— — —
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	— —	— —	— —
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping 	— — — — — — — —	— — — — — — — —	— — — — — — — —

Satya Service Station, L Block, Harsi Nagar,
ND-64.

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
15.	Exit Signage.			
16.	Provision of Lifts:			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	—
17.	Standby power supply	Required	62.5 KVA	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
20.	Special Fire Protection System for Protection of special Risks, if any:			
		—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

- Note :-
- ① There are three rooms (at the rear side of petrol pump office building) on first floor served by one staircase of one mtr. width, having store for office.
 - ② There are facilities of wheel balancing, wheel alignment, servicing of cars, Air Compressor, Pollution Control Centre kiosk, Puncture kiosk, spare parts sale kiosk etc at the rear office of Petrol Pump.
 - ③ No smoking boards were found displayed in Hindi & English. Fire buckets filled with sand placed near retail points.

Signature of Inspecting Officer

Name Sandeep Duggal

Designation Asst. Divisional officer.

Signature of Inspecting Officer

Name

Designation