

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFs/msl/school/2013/w2/703

Dated: 13/08/2013

FIRE SAFETY CERTIFICATE

Certified that the Govt, Sarvodaya Vidyalaya, Chand pur Majra, Delhi is comprised of Two Blocks Ground + One upper floor and Ground Floor Only owned/occupied by Sarvodaya Vidyalaya, Chand pur Majra, have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 19/07/2013 in the presence of Mr. Harveer Singh, (Principal) and that the building / premises is fit for occupancy of Educational building with effect from 13 / 08 /2013 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building bye laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 13/08/13 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Govt, Sarvodaya Vidyalaya, Chand pur Majra, Delhi
2. The Director of Education, Old Secretariat, Delhi.



INSPECTION REPORT

Ground floor
(Gr + one floor)
one pot/cabin Block

1. Name & address of the building: Govt Saraswodaya vidyalaya Chandpur Majara, Selh-40
2. Type of Occupancy : Educational
3. Type of Case : New Case / Renewal
4. Details of previous NOC : NO
5. Fire Safety directives letter No : NO
6. Date of inspection : 2-7-13
7. Name of the Inspecting Officers : K.K. SAXENA ADO
8. Name and designation of officers from the building side : Harveer Singh V-Principle
9. Year of Construction : 1974
10. Applicant's letter No. : SVC.PM/464/23/3-6-13 dt - 3-6-13

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<u>Accessable</u>	<u>Accessable</u>	<u>M/R</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<u>2</u> <u>-</u>	<u>2</u> <u>-</u>	<u>M/R</u> <u>-</u>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<u>150cm</u>	<u>2.5% @ 150cm</u>	<u>M/R</u>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	<u>1 m²</u>	<u>1 m²</u>	<u>M/R</u>
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain 		<u>N/A</u>	

Fire Extinguishers				
	<ul style="list-style-type: none"> Total numbers Types IS marking 	12 ABC ISI marked	12 ABC ABC yes	n/a n/a n/a
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm	N/A	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 		N/A	
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 		N/A	
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 		N/A	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 			
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump 		N/A	

14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers..... NIL

Signature of the Inspecting Officer

Name

Designation

DD (N/A)
Quish
22/7/13

Signature of the Inspecting Officer

Name

Designation

K.K. SAXENA
22/7/13
ADD