

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

E-mail:- [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)

Fax:- 011-23412593

No.F.6/DFS/MS/School/2013/52/713

Dated: 14/08/13

FIRE SAFETY CERTIFICATE

Certified that the building of **Holy Child Model School** located at Gopal Nagar, Najafgarh, New Delhi-110043 comprised of ground floor plus one upper floor, having total 28 rooms (Including Class Rooms, Math Lab, Library, Sci. Lab, Comp. Room, Sports Room, Store & Office etc.) was issued NOC by this department vide letter No.F.6/DFS/MS/2010/2636 dated 09.09.2010. The School building was re- inspected by the officer concerned of this department on 03.08.2013 in the presence of Sh. Satish Kumar Sehrawat (Chairman) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on.....14/08/13..... at New Delhi.

  
(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:- 011-23414333

Copy to:-

1. The Chairman,  
Holy Child Model School,  
Gopal Nagar, Najafgarh, N.D-43.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi – 110054.

GC  
CNY

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N/3

Ground plus one floor.**INSPECTION REPORT**

1. Name & address of the building: Holy Child Model School, Gopal Nagar, Najafgarh, ND-43
2. Type of Occupancy : Educational.
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F6/DFS/MS/2010/2536 Dated 09/09/10
5. Fire Safety directives letter No :
6. Date of inspection : 03/08/2013
7. Name of Inspecting Officer : ADO Sandeep Duggal
8. Name and designation of officers  
From the building side : Mr Satish Kumar Sehrawat (Chairman)
9. Year of Construction : 1983.
10. Applicant's letter No. : Nil dated 18/07/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	<u>Accessible</u>	<u>05 mtr</u>	<u>MR</u>
	• Gate width	<u>—</u>	<u>210, 268, 128, 153 cms</u>	<u>MR</u>
	• Width of internal road	<u>—</u>	<u>—</u>	<u>—</u>
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	<u>02</u>	<u>02</u>	<u>MR</u>
	• Basements	<u>—</u>	<u>—</u>	<u>No Basement</u>
	b. Width of staircases			
	• Upper Floor	<u>—</u>	<u>136 &amp; 126 cms</u>	<u>MR</u>
	• Basements	<u>—</u>	<u>—</u>	<u>No Basement</u>
	c. Protection of exits			
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• pressurization	<u>—</u>	<u>—</u>	<u>—</u>
	d. No. of continuous staircases to terrace	<u>—</u>	<u>one</u>	<u>—</u>
	e. Width of Corridor	<u>—</u>	<u>64 &amp; 170 cms</u>	<u>MR (old case)</u>
	f. Door Size	<u>—</u>	<u>98 cms</u>	<u>(old case) MR</u>
3.	<b>Compartmentation</b>			
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• Sealing of electrical shafts	<u>—</u>	<u>—</u>	<u>—</u>
	• Fire Rating of shaft door	<u>—</u>	<u>—</u>	<u>—</u>
	• Water Curtain	<u>—</u>	<u>—</u>	<u>—</u>
	• Fire Dampers	<u>—</u>	<u>—</u>	<u>—</u>
4.	<b>Smoke Management System</b>			
	• Basements	<u>30 a/c per hour</u>	<u>—</u>	<u>—</u>
	• Upper floors	<u>—</u>	<u>Natural ventilation</u>	<u>MR</u>

N/y

12 a/c per hour

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI marking</li> </ul>	<p>09 Nos ABC &amp; CO<sub>2</sub> ISI marked</p>	<p>Provided <del>do</del> ISI marked</p>	<p>MR MR MR</p>
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	<p>30 m 5 mm</p>	<p>Provided <del>do</del> <del>do</del></p>	<p>— — —</p>
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	<p>— — — — —</p>	<p>— — — — —</p>	<p>— — — — —</p>
8.	MOEFA			
9.	Public Address System		Provided	—
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	<p>— — —</p>	<p>— — —</p>	<p>— — —</p>
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	<p>— — —</p>	<p>— — —</p>	<p>— — —</p>
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	<p>— —</p>	<p>— —</p>	<p>— —</p>
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level               <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual stopping</li> </ul> </li> </ul>	<p>— — — — — — — —</p>	<p>— — — — — — — —</p>	<p>— — — — — — — —</p>

N/G

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to ~~grant~~ <sup>Renewal of</sup> Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note :- The Hose reel provided as per old DOE circular no 262-362 dt 17/1/05 has deteriorated and is partially functional on First floor only, but it is not required in current DOE circular dt 01/03/2011, hence FSC is recommended pl.

Sandeep  
06/8/13

Signature of Inspecting Officer

Name

Sandeep Duggal

Designation

Asstt. Divisional Officer

Signature of Inspecting Officer

Name

Designation

