

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001**

Fax: 23412593 E-mail:cfhq.dlfire@nic.in

No *F6/DFS/MS/School/2013/NO2/765* Dated *21/08/13*

**FIRE SAFETY CERTIFICATE**

Certified that the Bapu Public School, Delhi Gandhi Smarak Nidhi, Patpar Ganj, Delhi. comprises of ground & first floor was granted NOC by this deptt. vide letter No. F6 / DFS / MS / 10 / 1014 dated 06- 04- 2010 for ground floor only. The premises was re-inspected by the officer concerned of this department on 18-07-2013 in the presence of Sh. D.C.Premi, office Supdt. and found that the School using ground & first floor for classes have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education and that the building is fit for occupancy class B "Educational Building" with effect from *21-8* - 2013 for a period of three year, subject to conditions printed overleaf.

Issued on *21/08/13* at New Delhi.



(DR.G.C.MISRA)  
Chief Fire Officer  
Delhi Fire Service  
Ph. 23414333

Copy to:-

1. The Manager  
Bapu Public School  
Delhi Gandhi Smarak Nidhi,  
Patpar Ganj, Delhi – 110091.
2. The Director Education,  
Government of N.C.T Delhi.  
Old Sectt, Delhi 110054

### Condition

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, the management shall be responsible.
4. The clarification with regards to electrical installation, ventilation, structure stability set back areas, occupancy and construction deviation in building etc. may be got verified from the authorities concerned.
5. This certificate can not be treated in any case for regularization of unauthorized construction, unauthorized use of land, if any.
6. The owner/occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

-N/2-

## INSPECTION REPORT

1. Name & address of the building: Babu Public School Delhi Gandhi  
Smarak Nidhi, Patpar Ganj, Delhi.
2. Building is comprised of : Ground & First floor
3. Type of Occupancy : Educational.
4. Type of Case : Renewal
5. Details of Previous NOC letter: F6/MS/DFS/10/1014 dated 6.4.2010
6. Fire Safety direction letter No : NA
7. Date of Inspection : 18-07-2013
8. Name of the Inspecting officers: Gurmukh Singh ADO (LN)
9. Name and designation of Officer: Sh. D.C.Premi (office supdt.)  
from the building side
10. Year of Construction : 1990
11. Applicant's letter No : BPS/DGSN/PPG/213/1341 dated  
02-07-2013

S.N O.	Minimum Standards on fire prevention and fire safety U/R33	Director Education /Existing	Provided at Site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"><li>• Road width</li><li>• Gate width</li><li>• Width of internal road</li></ul>	Accessible	50 ft	MR
		Accessible	4Mtrs.	MR
		NA	NA	NA
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"><li>• Upper Floor</li><li>• Basement</li></ul>	2Nos.	2Nos.	MR
		NA	NA	NA
	B. Width of Staircases			
	<ul style="list-style-type: none"><li>• Upper Floor</li><li>• Basement</li></ul>	1.5Mtr or Less	1.6Mtr.& .96Mtrs	MR
		NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none"><li>• Fire check door</li><li>• Pressurization</li></ul>	NA	NA	NA
		NA	NA	NA
	e. No. of continuous staircases to terrace	01 No.	01No.	MR
	g. Width of Corridor	1.5Mtr or less	1.0Mtr	MR
	h. Door Size	1.0 mtr wide	1.0 mtr wide	MR





A/3-

M

3	Compartmentation.	NA		
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire rating of shaft door	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.	NA		
	• Basement	NA	NA	NA
	• Upper floor	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	3Nos.	7 Nos.	MR
	• types	ABC&CO2	ABC& CO2	MR
	• ISI marking	Required	Provided	MR
6	First-aid-Hose Reels.	NA		
	• Total numbers at ground floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system.	NA		
	• Type of detectors	NA	NA	NA
	• Location of main panel	NA	NA	NA
	• Location of repeater panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	Hooter's location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.	NA	NA	NA
	• Basement	NA	NA	NA
	• upper floor	NA	NA	NA
	• sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants	NA	NA	NA
	• size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.	NA	NA	NA
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.	NA	NA	NA
	• Ground Level	NA	NA	NA

*[Handwritten signature]*

- 1/1 -

Bapu Public School,  
Rohini, Delhi.

	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the Pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for Fire Fighting.	NA	NA	NA
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.	NA	NA	NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication in lift car	NA	NA	NA
	• Firemen's grounding switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.	NA	NA	NA
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire Control Room	NA	NA	NA
	• Detector system panel	NA	NA	NA
	• Flow switch panel	NA	NA	NA
	• PA system panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA

*ms*



-N/5-

20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA
----	--	----	----	----

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the Circular of Director Education, GNCTD in the light of office order No. F2/DFS/HQRS/300 dated 18-04-2012 it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.



  
Signature of the Inspecting Officer

Name - Gurmukh Singh

Designation ADO (LN)

DO (E)