

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/2013/ 718

Dated: 18/08/2013

FIRE SAFETY CERTIFICATE

Certified that the Bhardwaj Model School at RZQ-88, (Near Q Block Gurdwara) Nihal Vihar, New Delhi-110041, comprised of ground and one upper floors owned / occupied by Bhardwaj Model School, has already been issued Fire Safety Certificate vide letter No.F6/DFS/MS/09/3283 dated 06.11.2009 have deemed complied with the fire prevention and fire safety requirements in accordance with circular issued by Directorate of Education, Govt. of NCT of Delhi vide letter No. 262-362 dated 17.01.2005 and verified by the officer concerned of Fire Service on 19.07.2013 in the presence of Sh. Sanjay Bhardwaj (Manager) and that the building/premises is fit for occupancy class Educational with effect from 18/08/2013 for a period of three years subject to conditions printed below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 18/08/13 at New Delhi by.


(SANTOKH SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Phone:-23414250
E-mail: cfowz.dfire@nic.in

Copy to :-

1. The Manager, Bhardwaj Model School, RZQ-88, (Near Q Block Gurdwara) Nihal Vihar, New Delhi-110041.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.

ok
any

INSPECTION REPORT

1. Name & address of the building: Bhardwaj Model School
RZQ-82, Nihal Vihar, Delhi-41
2. Type of Occupancy : Educational (G+1)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No FG/DFS/MS/2010/2171 dt 22/7/10
5. Fire Safety directives Letter No. : DOE circular dt 17/01/2005
6. Date of inspection : 19/7/2013
7. Name of the Inspecting Officer : A.K. Jaiswal
8. Name and designation of Officer
from the building side : Sanjay Bhardwaj (Manager)
9. Year of Construction : 2005
10. Applicant's letter No. : Nul dt 3/7/13

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL DOE 17.1.05 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 Mtr	Provided	MR
	• Gate width	5 Mtr	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	1.50 Mtr.		
	• Upper floors	1.50 Mtr.	1.50 x 1	MR
	• Basements	Not Applied	Not Applied	Not Applied
	c. Protection of exits			
	• Fire check door			
	• Pressurization		NR	
	d. No of continuous staircase to terrace			
	e. Width Of Corridor	1.50 Mtr.	Provided	MR
	f. Door Size	1.00 Mtr.	Provided	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			NR
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	open to sky	NR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	5	6	NR
	<ul style="list-style-type: none"> • Types 	ABC/CO ₂	Provided	NR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	NR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	one at each floor	Provided	NR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 Mtr.	Provided	NR
	<ul style="list-style-type: none"> • Nozzle diameter 	6.5 mm	Provided	NR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detector • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			NR
8.	MOEFA			NR
9.	Public Address System			NR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 			
	<ul style="list-style-type: none"> • Upper Floor 			NR
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 			

		Required	Provided	NR
15	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft			NR
	➤ Pressurization of lift lobby			
	➤ Communication in lift Car			
	➤ Fireman's Grounding Switch			
	➤ Lift Signage			
17.	Standby power supply			NR
18.	Refuge Area			NR
	➤ Total area			NR
	➤ Location			
19.	Fire control room			
	➤ Detector system panel			NR
	➤ Flow Switch Panel			
	➤ PA System Panel			
	➤ Batter backup			
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;	No	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue ~~shortcomings as noted at serial numbers~~

N-9

AK Jaiswal
19/7/13

Signature of the Inspecting Officer

Name

(A.K. JAISWAL)

Designation

ADDG/(JOP)

Signature of the Inspecting Officer

Name

Designation