

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID: cfhq.dlfire@nic.in

No F6/DFS/MS/2013/school/1221760

Dated: 20/08/13

FIRE SAFETY CERTIFICATE

Certified that the Harcourt Butler Sr. Sec. School at Mandir Marg, New Delhi - 110001 owned / occupied by Harcourt Butler Sr. Sec. School building comprised of ground and first floor have compiled with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01-03-2011 and verified by the officer concerned of Delhi Fire Service on 16-07-2013 in the presence of Mrs. Alka Choudhary (Principal) and that the building is fit for occupancy class B "Educational Building" with effect from -----20/08/13 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions rule 38 of the Delhi Fire subject to the condition printed overleaf.

Issued on20/8/13..... at New Delhi by.



(Dr G.C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. The Harcourt Butler Sr. Sec. School, Mandir Marg, New Delhi - 110001
2. The Director Education, Old Secretariat, Delhi – 110054.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building : HARCOURT BUTLER Sr. Sect. School
MANDIR - MARI

2. Type of Occupancy : Educational G+Ist floor

3. Type of Case : Fresh

4. Details of previous NOC : NA

Fire Safety directives Letter No. : NA (As per Director of Relucting committee)

Date of inspection : 16/7/13

Name of the Inspecting Officer : M.K. Sharma (Assistant Divisional Officer)

Name and designation of Officer from the building side : Mrs. Alka Chandelhy Principal

Year of Construction : 1815

10. Applicant's letter No. : HB/2013-14/235 Dt 8/7/13

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site (PSS Area)	Remarks MR/NMR (P.S.S Area)
1.	Access of building			
	• Road width	9 mt	15 MT	MR
	• Gate width	NA	2 mt	MR
	• Width of internal road	NA	2 MT	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	02+3	P	MR
	• Upper floors	R	P	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mt	1.7 MT, 1.5, 1 MT	MR
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	d. No of continuous staircase to terrace			
	e. Width Of Corridor			
	f. Door Size			
3.	Compartmentation			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke managements System			
	• Basements			

5	Fire Extinguishers			
	• Total numbers	R	P	MR
	• Types	10	P	MR
	• IS marking	ABC, CO2	P	MR
		R	P	MR
6	First - Aid Hose Reels			
	• Total numbers on each floor			
	• Length of hose reel hose			
	• Nozzle diameter			
7	Automatic fire detection and alarming system			
	• Type of detectors			
	• Location of Main Panel			
	• Location of Repeater Panel			
	• Alternate source of power			
	• Hooters' Location			
8	MOEFA			
9	Public Address System	NR	P	MR
10	Automatic Sprinkler System			
	• Basements			
	• Upper Floor			
	• Sprinkler above false ceiling			
11	Internal Hydrants			
	• Size of riser/down-comer			
	• Number of hydrants per floor			
	• Hose Box			
12	Yard Hydrants			
	• Total number of hydrants			
	• Hose Box			
13	Pumping Arrangements			
	○ Ground Level			
	• Discharge of main pump			
	• Head of main pump			
	• Number of main pumps			
	• Jockey pump out put			
	• Jockey pump head			
	• Standby Pump out put			
	• Standby Pump Head			
	• auto Staring/Manual stopping			
	• Pump House Access			
	○ Terrace level			
	• Discharge of pump			
	• Head of the pump			
	• Power supply			
	• Auto starting of pump			
14	Captive water Storage for fire fighting			
	• Under ground tank capacity			

7/11

			NA	
15	Exit Signage	R	P	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of lift lobby • Communication in lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area • Location 			
19	Fire control room			
	<ul style="list-style-type: none"> • Detector system panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any;	R	CO ₂ , ABC	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / ~~issue shortcoming as noted at serial numbers:~~.....

Signature of the Inspecting Officer

Name :-
Designation :-

Signature of the Inspecting Officer

Name :-
Designation :-

DO (C)

All check in circular regarding requirements of P. A system
25/3/19.

M. J. SHARMA
25/3/19

M. J. SHARMA
ADD (CC)