

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/2013/FH/724

Dated: 19/08/2013

FIRE SAFETY CERTIFICATE

Certified that the Jeet Farm, located at, Alipur Narela Road, Delhi comprised of Basement + Ground floor built on a plot area of 3.0 acre land with covered area of approximately 250 square yard is owned / occupied by Sh Jitender Khanna, have complied with the fire prevention and fire safety Requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of fire service on 03/08/2013 in the presence of Sh Jitender Khanna, and that the building / premises is fit for occupancy Class Sub Div. D-5 Assembly Buildings with effect 19 / 08 /2013 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

1. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
2. The fire suppression / protection arrangements provided are to minimize losses, if maintained in good working condition. These systems cannot give a guarantee that there will be no fire or losses in the event of one.
3. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
4. This report may not in any way be treated as regularization of unauthorized construction, if any. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. The trained fire fighting staff should be available round the clock.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 19/08/2013 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
cfowz.dlfire@nic.in

Copy to:

1. The Executive Engineer (Building), Municipal Corporation of Delhi, Narela Zone, Zonal Office Building, Narela, Delhi with reference to the letter No AC/NRZ/2013/242 dated 30/07/2013
2. Sh Jitender Khanna, Jeet Farm Alipur Narela Road, Delhi

N-3

May kindly see the **letter No AC/NRZ/2013/242 dated 30/07/2013** received from Assistant Commissioner (MCD), Narela Zone regarding issuance of NOC from fire safety and fire prevention point of view in respect of **Jeet farm** located at **Alipur Narela Road**, Delhi for holding social function such as wedding and parties etc.

Accordingly the farm house premise was visited and inspected by the undersigned along with **DO (NW)** and **Sh Jitender Khanna** on **dated 03/08/2013** as per **Delhi Fire Service Act, 2007 and Delhi Fire Service Rules, 2010** and it was observed that the farm house is comprised of **Basement + Ground floor** having a **total plot area of approx 3.0 acre**. The permanent structure covers approximately **250 sq yards**. There was no electric over head wiring.

Remaining portion is open green, temporary shed, parking and road etc. No permanent sitting arrangement was seen at the time of inspection. The premise is approachable from approx 60 feet wide road. There was no electric over head wiring.

**As regards to the fire protection arrangements, the status is as under.**

S/NO.	Fire Safety Provision	Provided / Not Provided
1.	Access to building	Accessible & NOC already issued by team.
2.	Number, width type and arrangement of exits	1 Mtr ✓
3.	Protection of exits by means of fire checks door (s) and or pressurization.	N/A
4.	Compartmentation	Not required ✓
5.	Smoke Managements system	Not required ✓
6.	Fire Extinguishers	05 ABC, Provided and found functional ✓
7.	Fire Aid Hose Reels	Provided and found functional ✓
8.	Automatic Fire detection and alarming system	Not required
9.	MOEFA	Provided and found functional ✓
10.	Public Address System	Not required
11.	Automatic sprinkler system	Provided and functional
12.	Internal Hydrants and Yard Hydrants	Provided and found functional
13.	Pumping Arrangements 900 LPM	900 LPM provided. ✓
14.	Captive water Storage for fire 15000 ltr	15000 ltr ✓
15.	Exits Signage	Provided ✓
16.	Provision of lifts	Not required, No lift
17.	Standby power supply	Not required, but found provided ✓
18.	Refuge Area	Not required ✓
19.	Fire Control Room	Not required
20.	Special fire protection systems for protection of special risks	Not required



Case is recommended please.