

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. FE/DFS/MS/School/2013/W2/741 Dated: 19 / 08 / 2013

FIRE SAFETY CERTIFICATE

Certified that the **M.C. Primary Boys School** (name of the building or premises) located at **AC-Block, Shalimar Bagh, Delhi – 110088** comprised of Ground floor only, owned / occupied by **M.C. Primary Boys School**, have complied with the fire prevention and fire safety requirements in accordance with Director of education circular dated 01/03/2011 and verified by the officer concerned of Fire Service on **18/07/2013** in the presence of **Sh. K.L. Grover (Principal)** and the building/premises is fit for occupancy **Educational** with effect from 19 / 08 / 2013 for a period of **three years** subject to conditions printed below.

Issued on 19/08/2013 at New Delhi.


(SANTOKH SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, M.C.Primary Boys School, AC-Block, Shalimar Bagh, Delhi –88
2. The Director (Education), Govt. of NCT of Delhi, Old Sectt. Delhi.

Following fire safety directives must be adhered to

1. All the Means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **www.dfs.delhigovt.nic.in**.

- Nil -

(Ground Floor only)

INSPECTION REPORT

1. Name & address of the building : M. C. Primary^{Boys} School, A C-Block Shalimar^{Rajh}
2. Type of Occupancy : Educational
3. Type of Case : New Case/ ~~Renewal~~
4. Details of previous NOC : Letter No. — Dated: —
5. Fire Safety directives letter No : —
6. Date of inspection : 18/07/2013
7. Name of the Inspecting Officers : ADO S.K. Dua
8. Name and designation of officers from the building side : Sh. K.L. Grover, Principal
9. Year of Construction : 1983
10. Applicant's letter No. : Nil dated 01/7/13

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mtr	Provided	MR
	• Gate width	Required	Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	g. Width of Corridor	NA	NA	NA
	h. Door Size	1.0 mtr	1.10 mtr	MR

- 1/2

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types ABC-5 kg. • IS marking 	07 ✓ ISI marked	08 Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm		N/A
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			N/A
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 			N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	NA	NA

- N/A -

	<ul style="list-style-type: none">• Number of hydrants per floor• Hose Box		N/A	
12	Yard Hydrants.			
	<ul style="list-style-type: none">• Total number of hydrants• Hose Box		N/A	
13	Pumping Arrangements.			
	<ul style="list-style-type: none">• Ground Level<ul style="list-style-type: none">➤ Discharge of main Pump➤ Head of Main pump➤ Number of main pumps➤ Jockey Pump out put➤ Jockey pump head➤ Standby Pump out put➤ Standby Pump Head➤ Auto Starting/ Manual stopping➤ Pump House Access• Terrace level<ul style="list-style-type: none">➤ Discharge of pump➤ Head of the pump➤ Power Supply➤ Auto Starting of pump		N/A	
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none">• Underground tank capacity➤ Draw-off connection➤ Fire service inlet➤ Access to tank• Overhead Tank capacity		N/A	
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	<ul style="list-style-type: none">• Pressurization of Lift Shaft• Pressurization of Lift lobby		N/A	

- N/A -

	<ul style="list-style-type: none">• Communication In lift Car• Fireman's Grounding Switch• Lift Signage			
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none">➤ Total Area➤ Location		N/A	
19	Fire Control Room			
	<ul style="list-style-type: none">• Detector System Panel• Flow Switch Panel• PA System Panel• Batter backup• Building Floor Plans		N/A	
20	Special Fire Protection Systems for Protection of special Risks, if any:	No	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~



Signature of the Inspecting Officer

Name S.K. Dua

Designation ADO (wr)

Signature of the Inspecting Officer

Name

Designation