

c-5

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DGS/ms/school/2013/W2/731

Dated: 19/08/2013

FIRE SAFETY CERTIFICATE

Certified that the MC Primary Boys School, Ghevra, Delhi is comprised of Ground + One Upper floor owned/occupied by MC Primary Boys School have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education NBC- Part IV and verified by the officer concerned of Fire Service on 03/08/2013 in the presence of Sh. Ram Karan Dabas (Principal) and that the building / premises is fit for occupancy of Educational building with effect from 19/08/2013 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building bye laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 19/08/13 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, MC Primary Boys School, Ghevra, Delhi-110081
2. The Addl. Director of Education, NMCD, Civic Centre, Delhi.



N-1
Ground + one
Single Block.

INSPECTION REPORT

1. Name & address of the building: M.C. Prerna Boys School Ghewara Delhi-81
2. Type of Occupancy : Educational
3. Type of Case : New Case / ~~Renewal~~
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : Dir. of E.du.
6. Date of inspection : 3.8.13
7. Name of the Inspecting Officers : A.O. (B.W)
8. Name and designation of officers from the building side : Sh. Ram Karam Das Principal.
9. Year of Construction : 2008
10. Applicant's letter No. : Pl. No Nil dt. 3/8/13

PA-6509 m² CA 1100 m² NOS-207, NOCR-20 NOT-5+1

| | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|---|---|-----------------|-------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | Accessible | Accessible | M/R ✓ |
| | • Gate width | Accessible | Accessible | M/R ✓ |
| | • Width of internal road | Accessible | Accessible | M/R ✓ |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 2 | 2 | M/R ✓ |
| | • Basements | | | |
| | b. Width of staircases | | | |
| | • Upper Floors | 1.50 mtr | 1.70 mtr each | M/R ✓ |
| | • Basements | | | |
| | c. Protection of exits | | | |
| | • Fire check door | N/A | | |
| | • Pressurization | N/A | | |
| | e. No. of continuous staircases to terrace | | | |
| | g. Width of Corridor | | | |
| | h. Door Size | 1 mtr | 1 mtr double door | M/R ✓ |
| 3 | Compartmentation. | | | |
| | • Fire check door | | | |
| | • Sealing of electrical shafts | | | |
| | • Fire Rating of shaft door | | | |

| | | | | |
|----|---|--|--|--|
| 14 | Captive Water Storage for fire fighting. | | | |
| | <ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity | | | |
| 15 | Exit Signage. | | | |
| 16 | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage | | | |
| 17 | Standby power supply | | | |
| 18 | Refuge Area. | | | |
| | <ul style="list-style-type: none"> ➤ Total Area ➤ Location | | | |
| 19 | Fire Control Room | | | |
| | <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans | | | |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | | | |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....



Signature of the Inspecting Officer

Name

Designation *AO (N/w) Singh*
6/8/13

Signature of the Inspecting Officer *[Signature]*

Name

Designation *AO (B/w)*