

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/0 FS/MS/School/2013/W2/728

Dated: 19/08/2013

FIRE SAFETY CERTIFICATE

Certified that the **Radha Devi Public School, V-131, Shukra Bazaar Road Ph-I, Budh Vihar** is comprised of **Ground + Two Upper Floors** Owner/occupied by **Radha Devi Public School**, has already been issued fire safety certificate **vide letter no. F-6/DFS/MS/2010/75 dated 08/01/2010.** The premises was re-inspected by the officer from this department on dated **10/06/2013** in the presence of **Sh Harikesh Garg (Manager)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of **circular issued by Director of Education letter dated 17/01/2005** and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from 19/08/2013 for a period of **three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 19/08/13 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Radha Devi Public School, V-131, Shukra Bazaar Road Ph-I, Budh Vihar, Delhi
2. The Director of Education, Old Secretariat, Delhi-110054

INSPECTION REPORT

1. Name & address of the building : Radha Devi Public School, V-1/31, Shukra Bazaar Road, Ph-I, Budh Vihar (G + Two upper floors)
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F-6/DFS/MS/2010/75 Dated: 08/01/2010
5. Fire Safety directives letter No : NBC
6. Date of inspection : 10/06/2013
7. Name of the Inspecting Officers : ADO NP Sharma
8. Name and designation of officers
from the building side : Sh Harikesh Garg (Manager)
9. Year of Construction :
10. Applicant's letter No. : 27/04/2013

P.A. 300 Sq Yards C.A. 250Sq. Yards No's C.R.18 No S-275 No. ST-08

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|--------|---|-----------------|------------------|----------------|
| 1 | Access to building | Old case | | |
| | • Road width | Accessible | 30 | MR |
| | • Gate width | -- | 02mtr | MR |
| | • Width of internal road | -- | -- | -- |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 02 | 02 | MR |
| | • Basements | -- | -- | -- |
| | b. Width of staircases | | | |
| | • Upper Floors | Old case | Old case | Old case |
| | • Basements | -- | -- | -- |
| | c. Protection of exits | | | |
| | • Fire check door | -- | -- | -- |
| | • Pressurization | -- | -- | -- |
| | d. No. of continuous staircases to terrace | One | two | MR |
| | e. Width of Corridor | NA | NA | NA |
| | f. Door Size | -- | -- | -- |
| 3 | Compartmentation. | | | |
| | • Fire check door | -- | -- | -- |
| | • Sealing of electrical shafts | -- | -- | -- |
| | • Fire Rating of shaft door | -- | -- | -- |
| | • Water Curtain | -- | -- | -- |
| | • Fire Dampers | -- | -- | -- |
| 4 | Smoke Management System. | | | |

N-9

| | | | | |
|----|---|-----------|-----------|-------|
| 14 | Captive Water Storage for fire fighting. | | | |
| | <ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity | -- | -- | -- |
| | | -- | -- | -- |
| | | -- | -- | -- |
| | | -- | -- | -- |
| | | 5,000 Ltr | 5,000 Ltr | M/R ✓ |
| 15 | Exit Signage. | R | P | M.R. |
| 16 | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage | -- | -- | -- |
| | | -- | -- | -- |
| | | -- | -- | -- |
| | | -- | -- | -- |
| | | -- | -- | -- |
| 17 | Standby power supply | -- | -- | -- |
| 18 | Refuge Area. | | | |
| | <ul style="list-style-type: none"> ➤ Total Area ➤ Location | -- | -- | -- |
| | | -- | -- | -- |
| 19 | Fire Control Room | | | |
| | <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans | -- | -- | -- |
| | | -- | -- | -- |
| | | -- | -- | -- |
| | | -- | -- | -- |
| | | -- | -- | -- |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | -- | -- | -- |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspecting Officer

Name

Designation

D.O (N/W)
29/7/13

Signature of the Inspecting Officer

Name

Designation

N.P. SHARMA
297-13
A.D.O (R)