

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/School/2013/W2/736

Dated: 19 / 08 / 2013

**FIRE SAFETY CERTIFICATE**

Certified that the Uttaranchal Public School, Kamal Pur, Burari, Delhi is comprised of Ground + Three Upper Floors Owned/occupied by Uttaranchal Public School, has already been issued fire safety certificate vide letter no. F-6/DFS/MS/2010/397 dated 09/02/2010. The premises was re-inspected by the officer from this department on dated 12/07/2013 in the presence of Ms. Rajni Shukla and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of circular issued by Director of Education letter dated 17/01/2005 and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 19 / 08 / 2013 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 19/08/2013 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Uttaranchal Public School, Kamal Pur, Burari, Delhi-110084
2. The Director of Education, Old Secretariat, Delhi-110054

3/N Renewal

INSPECTION REPORT

1. Name & address of the building: Uttanchal Public School, Kamal pur, Barari, Delhi.
2. Type of Occupancy: Educational
3. Type of Case: : New Case/ Renewal
4. Details of previous NOC: : Letter No. F-6/DFS/ms/2010/397 Dated: 9-2-2010
5. Fire Safety directives letter No: Circular, Dir. of Edun. 17-1-2005.
6. Date of inspection: 12-7-2013
7. Name of the Inspecting Officers: ADO - SHYAM LAL
8. Name and designation of officers from the building side: Ms. Rajni Shukla.
9. Year of Construction: 2009, (Ground+3) ✓
10. Applicant's letter No.: NIL dated 25-6-2013

Old Case

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to building	<u>Circular, Dir. of Edun. 17/1/2005</u>		
	• Road width	<u>Accessible</u>	<u>6 m</u>	<u>MIR</u> ✓
	• Gate width	<u>-do-</u>	<u>2.6 m</u>	<u>MIR</u> ✓
	• Width of internal road	<u>NIA</u>	<u>NIA</u>	<u>NIA</u> ✓
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>2</u>	<u>2</u>	<u>MIR</u> ✓
	• Upper Floors	<u>2</u>	<u>2</u>	<u>MIR</u> ✓
	• Basements	<u>NIL</u>	<u>NIL</u>	<u>NIL</u>
	b. Width of staircases			
	• Upper Floors	<u>1.5 m</u>	<u>1 m &amp; 90cm</u>	<u>MIR (old case)</u> ✓
	• Basements	<u>NIL</u>	<u>NIL</u>	<u>NIL</u>
	c. Protection of exits			
	• Fire check door		<u>NIR</u>	
	• Pressurization		<u>/</u>	
	e. No. of continuous staircases to terrace	<u>1</u>	<u>Provided</u>	<u>MIR</u>
	g. Width of Corridor	<u>R</u>	<u>1 m</u>	<u>MIR (old case)</u> ✓
	h. Door Size	<u>1 m</u>	<u>95m (Two door)</u>	<u>MIR</u>
3	Compartmentation.		<u>(less than 15 student in each class)</u>	
	• Fire check door		<u>NIR</u>	
	• Sealing of electrical shafts		<u> </u>	
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	<u>30 a/c per hour</u>	<u>NIR</u>	
	• Upper floors	<u>12 a/c per hour</u>	<u>/</u>	



4/N

5	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	<p>06 ABC/CO2 (2.5kg) ISI marked</p>	<p>Provided Provided Provided.</p>	<p>MIR MIR MIR</p>
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	<p>one 30 m 5 mm</p>	<p>Provided Provided provided</p>	<p>MIR MIR MIR</p>
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>		NIR	
8	MOEFA			
			NIR	
9	Public Address System.			
			NIR	
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>		NIR	
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NIR	(NIR) provided 100mm	NIR
12	Yard Hydrants..			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>		NIR	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> <li>Ground Level               <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level               <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>		NIR	
		450 Lts/minute	provided	MIR
		40 m	provided	MIR
		NIR	NIR	NIR
		R	provided	MIR

5/2

14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>			NIR
		5000 Lts.	Provided	MIR
15	Exit Signage.	R	Provided	MIR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>			NIA
17	Standby power supply			NIR
18	Refuge Area.			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>			NIA
19	Fire Control Room			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>			NIR
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	Nil	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer *Do New*  
 Name *Do New*  
 Designation *18/7/13*

Signature of the Inspecting Officer *Shyam Lal*  
 Name *(SHYAM LAL)*  
 Designation *Assist. Divn. officer*