

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No: F.6/DFS/MS/School/2013/ W2/753

Dated: 19/08/13

FIRE SAFETY CERTIFICATE


Certified that the building of Sarvodaya Vidyalaya, located at East Punjabi Bagh, New Delhi - 110026 comprised of ground floor only, owned and occupied by Sarvodaya Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and verified by the officers concerned of Fire Service on 26-07-2013 in the presence of Ms. Asha Ahuja (Principal) and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B - 1 with effect from 19/08/13 for a period of three years subject to compliance of the conditions mentioned below:-

Issued on 19/08/13 at New Delhi.



(Santokh Singh)

Chief Fire Officer,
Delhi Fire Service.

 Email: cfowz.dfire@nic.in

Ph: 011 - 23414250

Copy to:-

1. The Principal,
Sarvodaya Vidyalaya,
East Punjabi Bagh, New Delhi - 110026
2. Director of Education,
Old Hindu College,
Old Secretariat Building,
Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Sarvodaya Vidyalaya, East Punjabi Bagh, New Delhi-110026
2. Type of Occupancy : Educational (School) Ground Floor only
3. Type of Case : NEW
4. Details of previous NOC : Letter No —
5. Fire Safety directives Letter No. : F.16/K.State/LL/2011/3298-3398 dated 1-3-11
6. Date of inspection : 26-07-13
7. Name of the Inspecting Officer : Mukesh Verma ADO(MN)
8. Name and designation of Officer from the building side : Ms. Asha Ahuja : Principal
9. Year of Construction : 1987
10. Applicant's letter No. : SY/EPO/2013/226 dated 5-7-13

Total area = 4.5 aera, covered area = 2631 m²

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided ✓	MR
	• Gate width	Accessible	Provided ✓	MR
	• Width of internal road	NA	NA	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1m	Provided	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		N/A	
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N/A	
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	11 @ 300m ² ABC & CO ₂ ISI marked	Provided ABC & CO ₂ Yes	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 		N/A	
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		N/A	
8.	MOEFA		N/A	
9.	Public Address System		N/A	
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 		N/A	

11.	Internal Hydrants			
	<ul style="list-style-type: none">• Size of riser/down- comer• Number of hydrants per floor• Hose Box			N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none">• Total number of hydrants• Hose Box			N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none">• Ground Level• Discharge of main pump➤ Head of main pump➤ Number of main pumps➤ Jockey pump out put➤ Jockey pump head➤ Standby Pump out put➤ Standby Pump Head➤ Auto Staring/Manual stopping➤ Pump House Access• Terrace level➤ Discharge of pump➤ Head of the pump➤ Power supply➤ Auto starting of pump			N/A
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none">• Under ground tank capacity➤ Draw of connection➤ Fire service inlet➤ Access to tank• Overhead Tank capacity			N/A
15	Exit Signage			N/A
16.	Provision of Lifts			

M/M

	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 			
17.	Standby power supply		N/A	
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 		N/A	
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Batter backup ➤ Building Floor Plans 		N/A	
20.	Special Fire Protection Systems for Protection of special Risks, if any;		N/A	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue ~~shortcomings~~ as noted at serial numbers



Signature of the Inspecting Officer

Name *Mukesh Verma*

Designation *ADD (MN)*

Signature of the Inspecting Officer

Name

Designation