


NO. F6/DFS/MS/School/2013/ SZ/ 768

DATED: 22/08/13

FIRE SAFETY CERTIFICATE

Certified that the Don Bosco School, at Alaknanda, New Delhi-110019 comprised of ground plus three upper floors was granted NOC by this department vide letter no. F6/MS/DFS/2006/1405 Dated 28.06.2006. The premises was re-inspected by the officers concerned of Fire Service on 30.07.2013 in the presence of Fr.. Babu Varghese SDB (Principal) and observed that fire safety norms as required under Rule 33 of Delhi Fire Service Rules, 2010 are deemed complied and that the building / premises is fit for occupancy class B "Educational building" with effect from 22/08/13.. for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 22/08/13..... at New Delhi by



(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

Copy to,

1. The Dy, Director, (Education), G.N.C.T..of Delhi, Defence Colony, New Delhi.
2. The Principal, Don Bosco School, at Alaknanda, New Delhi-110019

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Don Bosco School, Alaknanda, New Delhi-110019.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/MS/DFS/2006/1405 dated 28.06.2006		
5	Fire safety directives letter No	No		
6	Date of inspection	30.07.2013		
7	Name of the inspecting Officers :	D.O. (South) D.P. Bhardwaj, ADO D.B. Mukherjee		
8	Name and designation of officers from the building side	Fr. Babu Varghese SDB. (Principal)		
9	Year of construction			
10	Applicant's letter No.	Nil, 06.06.2013	(ground plus three upper floors) Two block ground plus three upper floor & one block stilt plus one upper floor.	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Old Case/NBC Requirement	Provided at site	Remarks MR / NMR
--------	-------------------------------------------------------------	--------------------------	------------------	---------------------

1	Access to building			Old Case
	1) Road width	Required	15 Mtr Provided	MR
	2) Gate width	Old Case	4.5 Mtr Provided	MR
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Old Case	2 Nos. Stairs ground to terrace, 1 no. stair ground to third floor, 1 no. stair ground to 1st terrace & 1 no. stair ground to 1st floor. Both block interconnected at 1st floor.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	Old Case	3 Nos. 1.5 Mtrs. 1 no. 1.4 mtr & 1 no. 1.35 mtr Provided	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	2 Nos Provided	MR
	e. Width of corridor	Old Case	1.5 Mtr	MR
	f. Door size	1 Mtr	Provided	MR

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Vent	MR

5	Fire Extinguishers			
	total numbers		30 Nos	MR
	Types		ABC, Water Co2 & Co2	MR
	ISI marking	ISI	Yes	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	Four	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 mm	Provided	MR
	Number of Hydrants per floor	Four	Provided	MR
	hose Box	Four	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	Required	450 & 450 LPM Provided	MR
	b. head of the pump	35 mtr	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	Old Case	1,00,000 Ltrs Provided	MR
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	Required	20,000 ltr. Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A

	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: N/A			

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.

Accordingly DFA is put up for your approval and signature please.

Signature of the inspecting officer



Name D. P. Bhardwaj

Designation : Divisional Officer (South)

Signature of the inspecting officer



Name D.B. Mukherjee

Designation : ADO (BCP)