

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax: 23412593, E-mail: cfohq.dfire@nic.in, Tel:- 011-23414333

NO.F6/DFS/MS/school/2013/52/775

Dated: 23/08/13

FIRE SAFETY CERTIFICATE

Certified that Govt. Priyadarshani Sarvodaya Kanya Vidyalaya, Fatehpur Beri, New Delhi-110074 School Code No.- 1923059 comprised of **Ground floor + 1 Upper floor only**, having total 66 rooms, owned/occupied by Delhi Administration was inspected by the officer concerned of this department on 02.08.2013 in presence of Mrs. Shiksha(Principal) and found that the school have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 issued by the Directorate of Education dated 01-03-2011 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the below mentioned conditions.

Issued on 23/08/13 at New Delhi by.

(Dr. G.C. Misra)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

OTC
19/8
ADP BLP

Copy to: -

The Principal,
Govt. Priyadarshani Sarvodaya Kanya Vidyalaya,
Fatehpur Beri, NewDelhi-110074

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

571

INSPECTION REPORT

Name & address of the building : Govt. Priyadarshani Sarvodaya Kanya Vidyalaya, Fatehpur Beri, New Delhi-110074 School Code No.- 1923059

1. Type of Occupancy : Educational
2. Type of Case : New Case
3. Details of previous NOC : N/A
4. Fire Safety directives letter No : F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01-03-2011.
5. Date of inspection : 02.08.2013
6. Name of the Inspecting Officers: ADO D.B.Mukherjee
7. Name and designation of officers
from the building side : Smt. Shiksha (HOS)
9. Year of Construction : 1989
10. Applicant's letter No. : GPD/SKV/FPB/2013/89 dated 04/07/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Required	Provided	MR
	• Gate width	Required	4 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Required	04	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	Required	1.25,1.41,1.45 & 1.88 mtrs each	MR
	• Basements	N/A	N/A	N/A
	•			
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	Required	Provided	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	N/A	N/A	N/A

✓

3	Compartmentation.	Not required		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.	Low-rise bldg, Not required		
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	N/A	N/A
		12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked	Provided 45Nos.	MR
			Provided ABC & Co2	MR
			Provided	MR
6	First-Aid Hose Reels.	Not required		
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 		N/A	N/A
		30 m	N/A	N/A
		5 mm	N/A	N/A
7	Automatic fire detection and alarming system.	Not required		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A

12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump			
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Not Applicable		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A

18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

The shortcomings issued vide letter no.F6/MS/DFS/School/2011/1478Dated 06/07/2011 has been rectified. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules as per the directives of Education Department vide Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01-03-2011 it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Note: The school building is comprised of ground floor plus one upper floor.

DO (South)

[Handwritten Signature]
6/8/13

Signature of the Inspecting Officer

[Handwritten Signature]
5/8/2013

