

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No: F.6/DFS/MS/School/2013/ 52/773

Dated: 23/08/13

FIRE SAFETY CERTIFICATE

Certified that the building of Nagar Nigam Prathmik Bal Vidyalaya (I & II Shift), located at Chaukhandi Old, New Delhi - 110018 comprised of ground plus one upper floor, owned and occupied by Nagar Nigam Prathmik Bal Vidyalaya (I & II Shift) have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and verified by the officers concerned of Fire Service on 01-07-2013 in the presence of Sh. Yogesh Sharma (Principal) and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B - 1 with effect from 23/08/13... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/08/13... at New Delhi.



(Santokh Singh)
Chief Fire Officer,
Delhi Fire Service.
Email: cfowz.dlfire@nic.in
Ph: 011 - 23414250

Copy to:-

1. The Principal,
Nagar Nigam Prathmik Bal Vidyalaya (I & II Shift),
Chaukhandi Old, New Delhi - 110018.
2. Director of Education,
North Delhi Municipal Corporation,
Dr. S.P.M Civic Centre,
Minto Road, New Delhi-110002



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N1

INSPECTION REPORT

- 1. Name & address of the building: Nagar Nigam Pashchim Bad Vidyalaya
(Chaukhanda Old II New Delhi - 110018)
- 2. Type of Occupancy : Educational (School) (G+1 upper floor)
- 3. Type of Case : NEW 18 class rooms
- 4. Details of previous NOC : Letter No —
- 5. Fire Safety directives Letter No. : Dir. of Educ. F-16/Estate/CC/Fire Safety/2011/3298-3398
- 6. Date of inspection : 01-07-13
- 7. Name of the Inspecting Officer : Mukesh Verma ADO(MN)
- 8. Name and designation of Officer Mr. Yogesh Sharma
from the building side : Principal
- 9. Year of Construction : —
- 10. Applicant's letter No. : NIL Dated 10-4-13

Total area = 4626 m², Covered Area = 758.5 m²

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2 x 1.5m	1. 173cms 2. 163cms	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.5m	225cms	MR
	f. Door Size	1m	2x110 cms	MR

N/A

MM

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		N/A	
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	4 @ 3000 ² ABC & CO ₂ ISI marked	Provided Provided Yes	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 		N/A	
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		N/A	
8.	MOEFA			
			N/A	
9.	Public Address System			
			N/A	
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 		N/A	

Internal Hydrants			
<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 			
	N/A		
12.	Yard Hydrants		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 		
	N/A		
13.	Pumping Arrangements		
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump 		
	➤ Head of main pump		
	➤ Number of main pumps		
	➤ Jockey pump out put		
	➤ Jockey pump head	N/A	
	➤ Standby Pump out put		
	➤ Standby Pump Head		
	➤ Auto Staring/Manual stopping		
	➤ Pump House Access		
	• Terrace level		
	➤ Discharge of pump		
	➤ Head of the pump	N/A	
	➤ Power supply		
	➤ Auto starting of pump		
	14.	Captive water Storage for fire fighting	
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		
	N/A		
15	Exit Signage		
N/A			
16.	Provision of Lifts		

N/4

	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 			
17.	Standby power supply		N/A	
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 		N/A	
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Batter backup ➤ Building Floor Plans 		N/A	
20.	Special Fire Protection Systems for Protection of special Risks, if any;		N/A	


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue ~~shortcomings as noted at serial numbers~~

.....

Signature of the Inspecting Officer *[Signature]*
 Name *Mukesh Verma*
 Designation *ADD(MN)*

Signature of the Inspecting Officer
 Name
 Designation


 DELHI FIRE SERVICE
 DIRECTOR CELL
 Date *14-8-13*
 Diary No. *830*