

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

Ph.23414333,Fax:23412593,E-mail:cfohq.dlfire@nic.in

No. F6/DFSI MS/EH/2013/NID2/1785

Dated: 23/8/13

FIRE SAFETY CERTIFICATE

Certified that the Restaurant at Shop No. -15,ground & first floor of L.S.C, O & P Mkt.Dilshad Garden, Delhi -95. comprised of basement, ground plus one upper floor owned/occupied by M/S Pummy's Food Zone,have complied with the fire prevention and fire safety requirements in accordance with N.B.C Part IV and verified by the officer concerned of Fire Service on 13.07.13 in the presence of Sh.Sagar Gupta (Manager) of restaurant and that the building (Ground & First floor) is fit for occupancy Group – D 'Assembly building' (Restaurant) with effect from ..... for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on.....23/08/2013.....at New Delhi by



(Dr.G.C.Misra)  
Chief Fire Officer  
Delhi Fire Service

O/c by

To,  
The Dy.Health Officer  
East Delhi Municipal Corporation  
Public Health Department,  
North Zone, Shahdara,Delhi.

Copy to:-  
M/s Pummy's Food Zone  
Shop No. -15,Hall 2,3 L.S.C  
O & P Mkt.Dilshad Garden ,Delhi -95.

### CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

INSPECTION REPORT

1. Name & address of the building:- M/s Pummy's Food Zone at Shop No. -15,ground & first floor, L.S.C, O & P Mkt.Dilshad Garden ,Delhi -95.
2. Building is comprised of : Basemenr,Ground + 1, upper floor.
3. Type of Occupancy : Assembly (Restaurant)
4. Type of Case : New Case
5. Details of Previous NOC letter : Nil
6. Fire Safety direction letter No : B.B.L 1983 & N.B.C part IV
7. Date of Inspection : 13.07.13
8. Name of the Inspecting officers: ADO Vijay Bahadur
9. Name and designation of Officer:  
from the building side : Sh.Sagar Gupta (Manager)
10. Year of Construction : 2006
11. Applicant's letter No : letter dated 19.06.13

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	Old Bldg. Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	0 6 Mtrs	06 Mtrs.	MR
	• Gate width	02 M	02 M	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	01 No.	02 Nos.	MR
	• Upper Floor	01 No.	02 Nos.	MR
	• Basement	01No.	02 Nos.	MR
	B. Width of Staircases	1.25 M	1.25 ,0.90 CM	MR
	• Upper Floor	1.25 M	1.25,0.90 CM	MR
	• Basement	1.25 M	1.25,0.90 CM	MR
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01 No.	02 Nos.	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2.0 Mtr.	2.0 Mtr.	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A

M/s Pummy's Food Zone at Shop No. -15, O & P Mkt.Dilshad Garden ,Delhi -95.



4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	06 nos.	08 nos.	MR
	• types	ABC	ABC	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	1no.	1no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
	• Basement 50 sqr yard	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	Required	Provided	MR
	• size of riser/down-comer	100 MM Dia	100 MM Dia	MR
	• Number of hydrants per floor	01 No.	01 No.	MR
	• Hose Box	01 No.	01 No.	MR
12	Yard Hydrants.	N/A	Provided	Acceptable
	• Total number of hydrants	N/A	01 No.	Acceptable
	• Hose Box	N/A	01 No.	Acceptable
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A

M/s Pummy's Food Zone at Shop No. -15, O & P Mkt. Dilshad Garden, Delhi -95.

1 RN-3

	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 lpm	450 lpm	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Auto	MR
14	Captive Water Storage for Fire Fighting.	Required	Provided	MR
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

DO (ED)

Signature of the Inspecting Officer

Name

Vijay Bahadur

