

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, E-mail: cfohq.dlfire@nic.in, Tel:- 011-23414333

NO. F6/DFS/MS/GH/2013/ 52/805

Dated: 26/08/13

FIRE SAFETY CERTIFICATE

Certified that Asian Guest House, 1119-22, Bazar Matia Mahal, Jama Masjid, Delhi-6, comprised of ground floor (commercial use), first floor (02 guest rooms, Reception, 02 store rooms), Second floor ((03 guest rooms + 01 store), third floor (01 guest room + 02 staff rooms), and fourth floor (01 Hall + Open area + Water tank) Total 05 rooms & hall, was granted NOC by this department vide letter No. F.6/MS/DFS/GH/2012/4578 Dated: 12-12-12. The premises was re-inspected by the officers concerned of this department on 25-07-2013 in the presence of Sh. Shahabuddin, owner of the guest house and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy of first floor (04 guest rooms, Reception), Second floor ((04 guest rooms), third floor (03 guest room), and fourth floor (01 Hall + Open area + Water tank) Total 11 rooms & hall, with effect from 26/08/13 for a period of 3 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 26/08/13 at New Delhi by.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1st floor, New Delhi.
2. M/s Asian Guest House, 1119-22, Bazar Matia Mahal, Jama Masjid, Delhi-6

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time.
- b. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- c. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- d. The trained fire fighting staff shall be available round the clock.
- e. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

17/11

INSPECTION REPORT

1. Name & address of the building: Asian Guest House, 1119/23, Bazar Matia Mahal
Jama Masjid, Delhi-6
2. Type of Occupancy: Lodging House
3. Type of Case: Addition of rooms.
4. Details of previous NOC: Letter No F.6/DFS/MS/GH/2012/4578 Dated 12/12/12
5. Fire Safety directives Letter No.: NIL
6. Date of inspection: 25-7-2013
7. Name of the Inspecting Officer: Sanjay Kumar (AOO, SPM)
8. Name and designation of Officer
from the building side
9. Year of Construction: 1980-81
10. Applicant's letter No.: 13666-68/Addl C.P./A/C (H) dated 19/3/13

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Spl. Area	09 mtr	MR
	• Gate width	-	Directly Accessible	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	-	-	-
	• Upper floors	01	01	MR (Old can)
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper floors	0.80 mtr	0.80 mtr	M.R.
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-	-	-
	• Fire check door		N	
	• Pressurization		A	
	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	.	N	
	f. Door Size		A	

18/11

3.	Compartmentation	N/A	-	-
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		N	A
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N	A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	08 Water CO ₂ & CO ₂ ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	one 30 mtr 5 mm	Provided	MR
			Provided	MR
			Provided	MR
7.	Automatic fire detection and alarming system		N/A	
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		N	A
8.	MOEFA		N/A	N/A
9.	Public Address System		Required	Provided
				MR
10.	Automatic Sprinkler System		N/A	
	<ul style="list-style-type: none"> • Basements • Upper Floor 			

Signature

19/11
Asian Guest House, Maha Mahal, Jama Masjid

	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants		N/A	
	• Size of riser/down-comer			
	• Number of hydrants per floor		N/A	
	• Hose Box			
12.	Yard Hydrants		N/A	
	• Total number of hydrants		N/A	
	• Hose Box		N/A	
13.	Pumping Arrangements		N/A	
	• Ground Level			
	• Discharge of main pump			
	➤ Head of main pump			
	➤ Number of main pumps			
	➤ Jockey pump out put			
	➤ Jockey pump head			
	➤ Standby Pump out put		N/A	
	➤ Standby Pump Head		A	
	➤ Auto Starting/Manual stopping			
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump	225 LPM	Provided	MR
	➤ Head of the pump	30 mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	-	Switch Provided at Reception	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	2500 lbs	Provided	MR
15	Exit Signage	Required	Provided	MR

[Signature]

20/N

16.	Provision of Lifts		N/A	
	➤ Pressurization of Lift Shaft			
	➤ Pressurization of lift lobby			
	➤ Communication in lift Car		N	
	➤ Fireman's Grounding Switch		A	
	➤ Lift Signage			
17.	Standby power supply			
18.	Refuge Area		N/A	
	➤ Total area		N	
	➤ Location		A	
19.	Fire control room		N/A	
	➤ Detector system panel			
	➤ Flow Switch Panel			
	➤ PA System Panel		N	
	➤ Batter backup		A	
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	One CO2 type fire extinguisher Provided near Elect. Panel	TFR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers



Signature of the Inspecting Officer

Name

Signature of the Inspecting Officer

Name Sanjay Kumar Tomar