

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/EH/2013/811

Dated: 26/8/13

FIRE SAFETY CERTIFICATE

Certified that the M/S De Forbidden Restaurant & Discotheque (A unit of De Forbidden Entertainment & Hospitality Pvt. Ltd.) located at 2nd floor, 108 to 112, Westend Mall, District Center, Janakpuri, New Delhi. The Westend Mall building is comprised of two tier basement, ground floor plus ten upper floors was issued FSC vide letter No. F.6/DFS/MS/2013/364 dated 24.05.2013. The restaurant & discotheque is running in above said Westend Mall building at 108 to 112, second floor only. The restaurant & discotheque having two exits owned/occupied by De Forbidden Entertainment & Hospitality Pvt. Ltd. The Restaurant & discotheque area at second floor was inspected by the officer concerned of this department on 31.07.2013 in the presence of Sh. Sirish Vohra (Director) and found that the management of De Forbidden Entertainment & Hospitality Pvt. Ltd have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class Group D assembly building Sub-Division D-6 w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....at New Delhi.

(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Dy. Health Officer (West Zone),
South Delhi Municipal Corporation,
Public Health Department, West Zone,
Rajouri Garden, New Delhi-110024.
(Ref. No. D/3112 HD/WZ/2013 dated 15.07.2013)
2. Sh. Sirish Vohra (Director),
De Forbidden Entertainment & Hospitality Pvt. Ltd.,
108 to 112, Westend Mall, District Center, Janakpuri, N.D-58.

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provisions of the Building Bye Laws, 1983.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

N/A

Two tier Basement, Ground plus ten upper floors.

The restaurant with discotheque running at second floor of above said building.

INSPECTION REPORT

with discotheque

1. Name & address of the building : M/S DE FORBIDDEN at 108 to 112, Westend Mall, Distt Centre, Janakpura, N Delhi-58
2. Type of Occupancy : Assembly
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. _____ Date _____
5. Fire Safety directives letter No : _____
6. Date of inspection : 31-07-2013
7. Name of Inspecting Officer : ADO Sandeep Duggal
8. Name and designation of officers
From the building side : Mr Sirish Vohra (Director)
9. Year of Construction : 2006-2007
10. Applicant's letter No. : D/3112 HD/WZ/2013 dated 15/07/13

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks
1.	Access to building <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible — —	18 mtr 05 mtr —	MR MR (old case) —
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases <ul style="list-style-type: none"> • Upper Floors • Basements 	five Eight, 01 Ramp	five Eight, 01 Ramp	MR (common) MR - do
	b. Width of staircases <ul style="list-style-type: none"> • Upper Floor • Basements 	— —	147, 148, 126, 126, 122 cms 150, 144, 128, 93 125 cms each (old case)	MR (old case) - do — do
	c. Protection of exits <ul style="list-style-type: none"> • Fire check door • pressurization 	Required —	Provided —	MR —
	d. No. of continuous staircases to terrace	—	four	—
	e. Width of Corridor	—	300 cms, 194 cms	—
	f. Door Size	—	210 cms, 107 cms 46 cms	MR
3.	Compartmentation <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required — do 01 Hrs —	Provided Sealed 01 Hrs —	MR MR MR —
4.	Smoke Management System <ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	Mechanical ventilation System	MR

N/10

		12 a/c per hour		
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	08 Nos CO ₂ , ABC, WCO ₂ ISI marked	Provided do ISI marked	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Two 30 m 5 mm	Provided do do	MR MR MR
7.	Automatic fire detection and alarming system			(one common hose reel)
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	— — — Required —	Provided Near Main Gate — Provided in staircase	MR MR — MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	do	do	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Required do —	Provided do —	MR MR —
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	— Four do	Provided do do	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	Four do	Four do	MR MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual stopping 	— 4500 lpm 70 m Two 180 lpm 70 m 4500 lpm 70 m Both	— 4500 lpm 70 m Two 180 lpm 70 m 4500 lpm 70 m Both	(Common with the mall) MR MR MR MR MR MR MR
(The fire pump are common for the building)				

N/11

M/s DE FORBIDDEN at 108 to 112, West end Mall,
Dist Centre, Janakpuri, WD-58.
(with discotheque)

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	Required	Provided	MR
		—	—	—
		—	—	—
		—	—	—
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	200000 Ltr	200000 Ltr	MR
		Required	Provided	MR
		— do	— do	MR
		— do	— do	MR
		30000 Ltr	30000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts:			(ART & Pump are common with the mall)
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	Required	Provided	MR
		— do	— do	MR
		— do	— do	MR
		— do	— do	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	256 Sq. m	MR
		—	5th 7th & 9th floor	MR
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	Required	Provided	MR
		—	—	—
		—	Provided	—
		—	— do	—
		—	—	—
20.	Special Fire Protection System for Protection of special Risks, if any:	—	—	—

N/12

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Note :- The M/s DE FORBIDDEN Restaurant with discotheque running at second floor (Area about -330 m² approx) of Westend Mall, Distt Centre, Janakpuri, The restaurant area having hose reel, MOEFA, sprinkler, Heat & smoke detector, Emergency light, fire Extinguishers, PA system & exit signs etc. The kitchen having two exits and the restaurant with discotheque also having two exits. The Westend mall building issued FSC by this department vide letter no. F6/DOS/MS/2013/364 dated 24/05/2013.

Signature of Inspecting Officer Sandeep Duggal 24/5/13

Name Sandeep Duggal
Designation Asstt. Divisional officer.

Signature of Inspecting Officer

Name
Designation