

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2013/W2/8/2

Dated: 26 / 08 / 2013

FIRE SAFETY CERTIFICATE

Certified that the **Kendriya Vidyalaya, A-2 Block, Keshavpuram** is comprised of Ground plus upper two floors owned/occupied by **Kendriya Vidyalaya, A-2 Block, Keshavpuram** complied with the fire prevention and fire safety requirements in accordance with, the **Circular No F.16/Estate/CC/Fire Safety/2011/3298 dated 01/03/2011** issued by Director of Education/ NBC - IV and verified by the officer concerned of Fire Service on **07/08/2013** in the presence of **Smt. Pushpa Rani Yadav (Principal)** and that the building / premises is fit for occupancy of **Educational** building with effect from 26 / 08 / 2013 for a period of **three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupied shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 26 / 08 / 13 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Kendriya Vidyalaya, A-2 Block, Keshavpuram, Delhi.
2. Kendriya Vidyalaya Sangthan, Delhi Region, JNU Campus, New Mehrauli Road, New Delhi - 110067

- N/A -

(Ground + two upper floors)

RE-INSPECTION REPORT → for point N. 5, 6, 13, 14 & 15 Pt.

1. Name & address of the building : Kendriya Vidyalaya, A-2 Block, Keshav Puram
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. _____ Dated: _____
5. Fire Safety directives letter No : D.O.E Circular dt. 01/03/2011
6. Date of inspection : 07/08/2013
7. Name of the Inspecting Officers : DO SIC Dua
8. Name and designation of officers from the building side : Smt. Pushpa Rani Yadav, Principal
9. Year of Construction : 1986
10. Applicant's letter No. : F-95/KVRP/2013-14/138 dt. 12/07/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement <i>D.O.E Circular dt. 01/03/2011</i>	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mtr.	Provided	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Three	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mtr.	1) 1.25m 2) 1.18m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	One	Provided	MR
	g. Width of Corridor	1.5 mtr.	Provided	MR
	h. Door Size	1.0 mtr.	1.0 mtr. with Door frame	MR

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	NA Open to sky	NA NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types ABC-5kg. • IS marking 	21 (Twenty one) ISI marked	25 (Twenty five) Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	Three 30 m 5 mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA	NA	NA	NA
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	NA	NA

	<ul style="list-style-type: none"> • Number of hydrants per floor • Hose Box 		N/A	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 		N/A	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 		N/A	
		450 LPM	450 LPM x 2	MR
		40 mtr.	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		-	-	-
		-	-	-
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		N/A	
		10,000 Lts.	10,000 Lts.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby 		N/A	

- 117 -

	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply	NR	NP	NA
18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:	No		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....



S.K. Dua
Signature of the Inspecting Officer

Name *S.K. Dua*
Designation *DN. Officer*

Signature of the Inspecting Officer

Name
Designation