

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/ms/school/2013/w2/795 Dated: 26/08 /2013

**FIRE SAFETY CERTIFICATE**

Certified that the **Govt. Boys Sr. Sec. School, SU- Block, Pitampura** is comprised of Ground plus upper two floors owned/occupied by **Govt. Boys Sr. Sec. School, SU- Block, Pitampura** complied with the fire prevention and fire safety requirements in accordance with, the **Circular No F.16/Estate/CC/Fire Safety/2011/3298 dated 01/03/2011** issued by Director of Education/ NBC - IV and verified by the officer concerned of Fire Service on **29/07/2013** in the presence of **Sh. Mahabir Singh ( Principal)** and that the building / premises is fit for occupancy of **Educational** building with effect from 26 / 08 / 2013 for a period of **three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service rules, 2010.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupied shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 26/08/13 at New Delhi

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
**cfowz.dlfire@nic.in**

Copy to:

1. The Principal, Govt. Boys Sr. Sec. School, SU- Block, Pitampura, Delhi.
2. The Director of Education, Govt. of NCT of Delhi.

- N/1 -

(Ground + Three upper floors)

**INSPECTION REPORT**

1. Name & address of the building : Govt. Boys Sr. Sec. School, SU Block, Pitampura
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No.                      Dated:
5. Fire Safety directives letter No : D.O. E circular dt. 01/02/2011
6. Date of inspection : 29/07/2013
7. Name of the Inspecting Officers : ADO (WP), S.K. Dua
8. Name and designation of officers from the building side : Sh. Mahabir Singh (Principal)
9. Year of Construction : 2001
10. Applicant's letter No. : Nil dt. 28/07/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6m	Provided	MR
	• Gate width	accessible	Accessible	MR
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	Four	Provided (04)	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mtr.	1) 1.7mtrs. 2) 1.86m	MR
	• Basements	—	3) 1.85m 4) 1.65m	—
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	One	Provided	MR
	g. Width of Corridor	1.5 mtr	Provided	MR
	h. Door Size	1.0 mtr	Provided (with d/frame)	MR

- N/2 -

7/11

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>		N/A	
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	N/A	
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	34 (Thirty four) Available ISI marked	75 Provided Provided	MR MR MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	03 at each floor 30 m 5 mm	Provided (03) do do	MR MR MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>		N/A	
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	Repd.	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>		N/A	
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	NA	NA	NA

- N/A -

	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>		N/A	
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>		N/A	
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>• Ground Level               <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level               <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>		N/A	
		450 LPM	(provided) 450 LPM X 2	MR
		40 mtr.	provided	MR
		Required	provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity               <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>• Overhead Tank capacity</li> </ul>		N/A	
		10,000 lts.	10,000 lts.	MR
15	<b>Exit Signage.</b>	Reqd.	provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> </ul>		N/A	

- N/A -

	<ul style="list-style-type: none"> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>			
17	<b>Standby power supply</b>			
18	<b>Refuge Area.</b>			
	➤ Total Area			
	➤ Location			
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>			
20	Special Fire Protection Systems for Protection of special Risks, if any:	No		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....



Signature of the Inspecting Officer

Name S.K. Dua

Designation ADO (WP)

Signature of the Inspecting Officer

Name

Designation

*(Handwritten signature)*