

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. 26/DFS/MS/School/2013/790

Dated: 26/08/2013

FIRE SAFETY CERTIFICATE

Certified that the Geetanjali Modern School, is comprised of Ground + one upper floor owned and occupied by Geetanjali Modern School located at A-2, West Sant Nagar, Burari, Delhi have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 12/07/2013 in the presence of Sh. Hari Kishan and that the building / premises is fit for occupancy of Group Class B (Educational) with effect from 26/08/13 for a period of three years, subject to compliance of the conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 26/08/13 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, Geetanjali Modern School, A-2, West Sant Nagar, Burari, Delhi
2. The Director of Education, Old Secretariat, Delhi

N-1

INSPECTION REPORT

1. Name & address of the building Geetanjali Modern School, A-2, Grah No. 13
2. Type of Occupancy Educational. - West Sant Nagar, Barrow, Delhi
3. Type of Case New Case/ ~~Renewal~~
4. Details of previous NOC : Letter No. NIL Dated: _____
5. Fire Safety directives letter No Circular, Dir. of Edun. 1/3/2011
6. Date of inspection 12-7-2013
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers
from the building side : Sh. Hari Kishan
9. Year of Construction 2010, (Ground + one)
10. Applicant's letter No. GMS/PC/13 dated 4.5.2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	<u>Circular, Dir. of Edun. Requirement 1/3/2011</u>	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessible</u>	<u>5 m</u>	<u>MIR</u>
	• Gate width	<u>-do-</u>	<u>2.5 m x 2</u>	<u>MIR</u>
	• Width of internal road	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>one</u>	<u>one</u>	<u>MIR</u>
	• Upper Floors	<u>one</u>	<u>one</u>	<u>MIR</u>
	• Basements	<u>NIL</u>	<u>NIL</u>	<u>NIL</u>
	b. Width of staircases			
	• Upper Floors	<u>1.5 m</u>	<u>1.53 m</u>	<u>MIR</u>
	• Basements	<u>NIL</u>	<u>NIL</u>	<u>NIL</u>
	c. Protection of exits			
	• Fire check door		<u>MIR</u>	
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor	<u>R</u>	<u>2.4 m</u>	<u>MIR</u>
	h. Door Size	<u>1 m</u>	<u>1.02 m</u>	<u>MIR</u>
3	Compartmentation.		<u>(one door, less than its standard.)</u>	
	• Fire check door		<u>MIR</u>	
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	30 a/c per hour	<u>N/A</u>	
	• Upper floors	12 a/c per hour		

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	2 on GF 2 on FF 04 ABC/CO2(2-5kg) ISI marked	Provided Provided Provided	MIR MIR MIR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm	NIR	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 		NIR	
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 		NIR	
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 		NIR	
12	Yard Hydrants..			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 		NIR	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 		NIR	

3/N

14	Captive Water Storage for fire fighting.		
	• Underground tank capacity		NIR
	➤ Draw-off connection		
	➤ Fire service inlet		
	➤ Access to tank		
	• Overhead Tank capacity		
15	Exit Signage.		
16	Provision of Lifts.		
	• Pressurization of Lift Shaft		NIA
	• Pressurization of Lift lobby		
	• Communication In lift Car		
	• Fireman's Grounding Switch		
	• Lift Signage		
17	Standby power supply		
18	Refuge Area.		
	➤ Total Area		NIA
	➤ Location		/
19	Fire Control Room		
	• Detector System Panel		NIR
	• Flow Switch Panel		
	• PA System Panel		
	• Batter backup		
	• Building Floor Plans		
20	Special Fire Protection Systems for Protection of special Risks, if any:		
		—	NIL

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

DA (NW)
Geetha
 22/7/13

Signature of the Inspecting Officer

Name (SHYAM CAZ)

Designation

Shyam
 18/7/2013
 Asstt. Divn. Officer