

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

E-mail:- [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)

Fax:- 011-23412593

No: F.6/DFS/MS/School/2013/52/818

Dated: 29/08/13

FIRE SAFETY CERTIFICATE

Certified that the main building of Govt. Sarvodaya (Co-Ed) Vidyalaya, L-Block, Hari Nagar, New Delhi -110064 comprised of ground floor plus two upper floors, having total 44 rooms (Including Class Rooms, Offices, Labs, Yoga Room, Music Room, Staff Room & Sports Room etc) owned/occupied by The Govt. of NCT of Delhi was inspected by the officer concerned of this department on 21.08.2013 in the presence of Smt. Nisha Kumari (Vice Principal) and found that the Govt. of NCT of Delhi have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on ...29/08/13.....at New Delhi

  
(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:- 011-23414333

Copy to: -

1. The Principal,  
Govt. Sarvodaya (Co-Ed) Vidyalaya,  
L-Block, Hari Nagar, New Delhi-110064.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi - 110054.

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

INSPECTION REPORT

1. Name & address of the building : Govt Samadaya (Co-ed) Vidyalaya, L-Block, Hari Nagar, N Delhi 110064
2. Type of Occupancy : Educational
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. \_\_\_\_\_ Date \_\_\_\_\_
5. Fire Safety directives letter No : \_\_\_\_\_
6. Date of inspection : 21-08-2013
7. Name of Inspecting Officer : ADO Sandeep Duggal
8. Name and designation of officers  
From the building side : Vice Principal Mrs Nisha Kumari
9. Year of Construction : 1981
10. Applicant's letter No. : Nil dated 16/07/2013

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NBC Requirement   | Provided at site                                     | Remarks                  |
|--------|---|-------------------|--|--------------------------|
| 1.     | Access to building  |                   |  | MR/NMR                   |
|        | • Road width  | <u>Accessible</u> | <u>7mtr</u>  | <u>MR</u>                |
|        | • Gate width  | <u>—</u>          | <u>4.60mtr</u>                                       | <u>MR</u>                |
|        | • Width of internal road                                    | <u>—</u>          | <u>—</u>   | <u>—</u>                 |
| 2.     | Number, Width, Type & Arrangement of Exits                  |                   |  |                          |
|        | a. Number of staircases                                     |                   |  |                          |
|        | • Upper Floors  | <u>03</u>         | <u>03</u>  | <u>MR</u>                |
|        | • Basements   | <u>—</u>          | <u>—</u>   | <u>No Basement</u>       |
|        | b. Width of staircases                                      |                   |  |                          |
|        | • Upper Floor   | <u>—</u>          | <u>143cms, 140cms &amp; 127cms</u>                   | <u>MR (old Building)</u> |
|        | • Basements   | <u>—</u>          | <u>—</u>   | <u>No Basement</u>       |
|        | c. Protection of exits                                      |                   |  |                          |
|        | • Fire check door   | <u>—</u>          | <u>—</u>   | <u>—</u>                 |
|        | • pressurization  | <u>—</u>          | <u>—</u>   | <u>—</u>                 |
|        | d. No. of continuous staircases to terrace                  | <u>—</u>          | <u>01</u>  | <u>—</u>                 |
|        | e. Width of Corridor  | <u>—</u>          | <u>236 to 242 cms</u>                                | <u>—</u>                 |
|        | f. Door Size  | <u>—</u>          | <u>Two (98cm to doors in each 100 cms) classroom</u> | <u>—</u>                 |
| 3.     | Compartmentation  |                   |  |                          |
|        | • Fire check door   | <u>—</u>          | <u>—</u>   | <u>—</u>                 |
|        | • Sealing of electrical shafts                              | <u>—</u>          | <u>Sealed</u>  | <u>—</u>                 |
|        | • Fire Rating of shaft door                                 | <u>—</u>          | <u>—</u>   | <u>—</u>                 |
|        | • Water Curtain   | <u>—</u>          | <u>—</u>   | <u>—</u>                 |
|        | • Fire Dampers  | <u>—</u>          | <u>—</u>   | <u>—</u>                 |
| 4.     | Smoke Management System                                     |                   |  |                          |
|        | • Basements   | 30 a/c per hour   | <u>—</u>   | <u>No Basement</u>       |
|        | • Upper floors  | <u>—</u>          | <u>Natural Ventilation</u>                           | <u>MR</u>                |





N/7

|     |   |            |             |         |
|-----|---|------------|-------------|---------|
|     | <ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>            | —          | —           | —       |
|     |   | 450 LPM    | Two 450 LPM | MR      |
|     |   | 30 m       | 36 m        | MR      |
|     |   | —          | —           | —       |
| 14. | <b>Captive Water Storage for fire fighting</b>  |            |             |         |
|     | <ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>                      | —          | —           | —       |
|     |   | —          | —           | —       |
|     |   | —          | —           | —       |
|     |   | —          | —           | —       |
|     |   | 10000 Ltrs | 10000 Ltrs  | MR      |
| 15. | <b>Exit Signage.</b>  | Required   | Provided    | MR      |
| 16. | <b>Provision of Lifts:</b>  |            |             |         |
|     | <ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul> | —          | —           | No lift |
|     |   | —          | —           | - do    |
|     |   | —          | —           | - do    |
|     |   | —          | —           | - do    |
|     |   | —          | —           | - do    |
| 17. | <b>Standby power supply</b>   | —          | —           | —       |
| 18. | <b>Refuge Area.</b>   |            |             |         |
|     | <ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>  | —          | —           | —       |
|     |   | —          | —           | —       |
| 19. | <b>Fire Control Room</b>  |            |             |         |
|     | <ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>                                  | —          | —           | —       |
|     |   | —          | —           | —       |
|     |   | —          | —           | —       |
|     |   | —          | —           | —       |
|     |   | —          | —           | —       |
| 20. | <b>Special Fire Protection System for Protection of special Risks, if any:</b>  | —          | —           | —       |

N/8

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Note :- The main school building is comprised of ground plus two upper floor. The school management has rectified all the shortcomings mentioned in letter no F6/DFS/MS/2012/4519 dated 07/12/12. FSC is recommended please.

Sandeep  
22/08/2013

Signature of Inspecting Officer

Name

Sandeep Duggal

Designation

Asst. Divisional Officer

Signature of Inspecting Officer

Name

Designation

