

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/EH/2013/W2/822 Dated: 29 / 08 / 2013

FIRE SAFETY CERTIFICATE

Certified that New Eleven to Eleven Restaurant located at Shop No 12, CSC-5, First floor, DDA Gole Market, Sector -9, Rohini, Delhi 110085 was granted NOC by this department vide letter no F-6 / DFS / MS / EH / 2010 / 1425 Dated 14/05/2010. The premises was re-inspected by the officers concerned of this department on 27 / 07 / 2013 in the presence of Sh. Nand Kishore Manager and found that the building have deem complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for Assembly occupancy with effect from 29 / 08 / 2013 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 29 / 08 / 13 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
cfowz.dlfire@nic.in

Copy to:

1. The Dy Health Officer, North Delhi Municipal Corporation, Health Department, Rohini Zone, Sector-V, Rohini, Delhi-110085 for information w r t letter No DHO/RZ/2013/ 391 dated 08/07/2013
2. The authorized signatory, New Eleven to Eleven Restaurant, Shop No 12, CSC-5, First floor, DDA Gole Market, Sector -9, Rohini, Delhi 110085

**INSPECTION REPORT**

1. Name & address of the building: *New Eleven to Eleven, SNO 12, CSC-5, 1st floor, DDA Gole market, sec-9, Rohini, Delhi.*
2. Type of Occupancy: *Assembly (Restaurant)*
3. Type of Case: *New Case / Renewal ✓*
4. Details of previous NOC: *FG/DFS/MS/EH/2010/1425 dtd 14/5/10*
5. Fire Safety directives letter No: *-*
6. Date of inspection: *27/7/13*
7. Name of the Inspecting Officers: *DO (NW)*
8. Name and designation of officers from the building side: *Sh Nand kishore (Manager)*
9. Year of Construction: *2005/2010*
10. Applicant's letter No.: *NIL dtd 9/7/13 / DHO/RZ/2013/391 dtd 8/7/13*

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	<i>Accessible</i>	<i>Accessible</i>	<i>m/r</i>
	• Gate width	<i>-</i>	<i>-</i>	<i>-</i>
	• Width of internal road	<i>-</i>	<i>-</i>	<i>-</i>
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	<i>02</i>	<i>02</i>	<i>m/r</i>
	• Basements	<i>-</i>	<i>-</i>	<i>-</i>
	b. Width of staircases			
	• Upper Floors	<i>old care</i>	<i>old care</i>	<i>m/r</i>
	• Basements	<i>-</i>	<i>-</i>	<i>-</i>
	c. Protection of exits			
	• Fire check door	<i>-</i>	<i>-</i>	<i>-</i>
	• Pressurization	<i>-</i>	<i>-</i>	<i>-</i>
	e. No. of continuous staircases to terrace	<i>01</i>	<i>01</i>	<i>m/r</i>
	g. Width of Corridor	<i>-</i>	<i>-</i>	<i>-</i>
	h. Door Size	<i>old care</i>	<i>old care</i>	<i>m/r</i>
3	<b>Compartmentation.</b>			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			

*N/A*

5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	1 CO <sub>2</sub> 2 WCO <sub>2</sub> ISI marked	1 CO <sub>2</sub> & 4 ABC yes yes	m/r m/r m/r
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01 30 m 5 mm	P P P	m/r m/r m/r
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>		N/A	
8	<b>MOEFA</b>	R	P	m/r
9	<b>Public Address System.</b>	-	-	-
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	- Regd -	- P -	- m/r -
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>		N/A	
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	R R	P P	m/r m/r
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> </ul> </li> </ul>	- - - 180 LPM 40 m - - R - 450 LPM	- - - P P - - P - P	- - - m/r m/r - - m/r - m/r

14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	—	—	—
	➤ Draw-off connection	NR	NP	N/A
	➤ Fire service inlet	R	P	m/R
	➤ Access to tank	—	—	—
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	5000 ltr	P	m/R
15	<b>Exit Signage.</b>	R	P	m/R
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	N/A		
17	<b>Standby power supply</b>	R	P	m/R
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A		
	➤ Location	N/A		
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> <li>Batter backup</li> <li>Building Floor Plans</li> </ul>	N/A		
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

DCIO (NW)

Signature of the Inspecting Officer

Name

Designation

8/8/13  
DO (NW)

