

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001
Fax: 23412593 E-mail:cfhq.dlfire@nic.in

No *FG/DP5/MS/812013/1102/824*

Dated *29/8/13*

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Kanya / Bal Vidyalaya Laxmi Nagar Delhi. comprises of three building blocks, A- Gr+3, B- Gr+1 & C- Gr+1 upper floors have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 16-07-2013 in the presence of Principal and that the premises is fit for occupancy of "Educational Building" with effect from *29-8-* 2013 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf.


Issued on *29/08/2013* at New Delhi.



(DR. G.C.MISRA)
Chief Fire Officer
Delhi Fire Service
Ph. 23414333

Copy to:-

1. The Principal,
Govt. Sarvodaya Kanya Vidyalaya
Laxmi Nagar Delhi -110092
2. The Director Education,
Government of N.C.T Delhi.
Old Sectt, Delhi 110054
3. The Principal,
Govt. Sarvodaya Bal Vidyalaya
Laxmi Nagar Delhi -110092



Condition

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, the management shall be responsible.
4. The clarification with regards to electrical installation, ventilation, structure stability set back areas, occupancy and construction deviation in building etc. may be got verified from the authorities concerned.
5. This certificate can not be treated in any case for regularization of unauthorized construction, unauthorized use of land, if any.
6. The owner/occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

-N/14-

INSPECTION REPORT

1. Name & address of the building: Govt. Sarvodaya Kanya/Bal
Vidyalaya Laxmi Nagar, Delhi - 92
2. Building is comprised of : 3 Blocks, A- Gr+3, B- Gr+1 & C- Gr+ 1
upper floors
3. Type of Occupancy : Educational.
4. Type of Case : Fresh
5. Details of Previous NOC letter: NA
6. Fire Safety direction letter No : NA
7. Date of Inspection : 16-07-2013
8. Name of the Inspecting officers: Gurmukh Singh ADO (LN)
9. Name and designation of Officer: Principal
from the building side
10. Year of Construction : Old Building
11. Applicant's letter No : dated 18-06-2013

S.N O.	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement.	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	6 Mtr.	18 Mtr	MR
	• Gate width	4.5 Mtr	5.0 Mtr.	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases		<i>A Block B Block C Block</i>	
	• Upper Floor	2Nos.	2Nos, 1No,2Nos	MR
	• Basement	NA	NA	NA
	B. Width of Staircases	NA	NA	NA
	• Upper Floor	1.5 Mtr or less	A-Gr.+3,1.25, 1.25,B -G+1,1.5, &C-G+1,1.4,1.4 Mtr.	MR
	• Basement	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	02Nos.	02Nos.	MR
	g. Width of Corridor	1.5 Mtr or less	1.2 Mtr.	MR

h

N/15

	h. Door Size	1.0 Mtr	1.0 Mtr	MR
3	Compartmentation.	NA		
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire rating of shaft door	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.	NA		
	• Basement	NA	NA	NA
	• Upper floor	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	18Nos.	25 Nos.	MR
	• types	ABC&CO2	ABC& CO2	MR
	• IS marking	Required	Provided	MR
6	First-aid-Hose Reels.			
	• Total numbers at ground floor	6 Nos	Gr. & First fl. 6 Nos each fl., 2 nd & 3 rd fl. 2Nos each fl.	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.	NA		
	• Type of detectors	NA	NA	NA
	• Location of main panel	NA	NA	NA
	• Location of repeater panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	Hooter's location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public address System.	NA	Provided	NA
10	Automatic Sprinkler System.	NA	NA	NA
	• Basement	NA	NA	NA
	• upper floor	NA	NA	NA
	• sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants	NA	NA	NA
	• size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.	NA	NA	NA
	• Total number of hydrants	NA	NA	NA

by

- 11/16 -

Govt. Sarvodaya Kanya Balvidyalaya,
Daxmi Nagar, Delhi

	• Hose Box	NA	NA	NA
13	Pumping Arrangements.	NA	NA	NA
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450LPM	450LPM	MR
	➤ Head of the Pump	40Mtr	40 Mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.	NA	NA	NA
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000Ltr.	10,000Ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	NA	NA	NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication in lift car	NA	NA	NA
	• Firemen's grounding switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.	NA	NA	NA
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire Control Room	NA	NA	NA
	• Detector system panel	NA	NA	NA
	• Flow switch panel	NA	NA	NA

h

- A/17 -

	<ul style="list-style-type: none">PA system panel	NA	NA	NA
	<ul style="list-style-type: none">Battery backup	NA	NA	NA
	<ul style="list-style-type: none">Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules and light of office order No. F2/DFS/HQRS/300 dated 18-04-2012 it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

Gurmukh Singh
A/8/13

Name – Gurmukh Singh

Designation ADO (LN)