

No. F6/DFS/MS/FW/2013/NO2/825


Dated: 30/08/13

FIRE SAFETY CERTIFICATE

Certified that the M/s Shri Hari Fireworks, Shop No. C-7, Kh. No. 182, New Modern Jagat Puri, Shahdara, Delhi-32 Proposed for running the trade of Sale and Possession of 300 Kg Fire Works and 1200 Kg Chinese sparkles at the ground floor of a building owned / occupied by Sh. Nitin Sharma and Sh. Rakesh Kumar have complied with the fire prevention and fire safety requirements in accordance with Guidelines issued by Additional Commissioner of Police (Lic.) and verified by the officer concerned of fire service on 01.08.2013 in presence of Mr. Nitin Sharma and that the Shop is fit for occupancy Class Fire works with effect from for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of conditions under rule 38 of Delhi Fire Service Rules-2010.

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time.
2. Any loss of life or property due to non functional of fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock when shop is open.
4. Any deviation w.r.t. construction etc. shall be verified by concerned building sanctioning authority.
5. This certificate may not be treated in any case for regularization of unauthorized construction, if any.

Issued on... 30/08/13 ..... at New Delhi by

  
(Dr. G.C. Misra)  
Chief Fire Officer  
Delhi Fire Service

*o/e*

**Copy to:-**

1. The Additional Commissioner of Police (Lic.), Police Station, First Floor, Defence Colony, New Delhi.
2. Sh. Nitin Sharma S/o Shri S.D. Sharma R/o 1/4462, Ram Nagar, Shahdara, Delhi and Sh. Rakesh Kumar S/o Sh. Ram Niwas R/o 1/4649/6-A, New Modern Shahdara, Mandoli Road, Delhi-32

IRN-1

### INSPECTION REPORT

1. Name & address of the building: M/s Shri Hari Fireworks at shop no.C-7,Kh.No.182,  
New Modern Jagat Puri, Shahdara, Delhi -32.
2. Type of Occupancy : Storage Fireworks
3. Type of Case : New Case
4. Details of Previous NOC : Nil
5. Fire Safety direction letter No : ----- *fresh case.*
6. Date of Inspection : 01.08.2013
7. Name of the Inspecting Officers : ADO Suresh Singh
8. Name of the Person from the : Sh.Nitin Sharma  
Building side
9. Year of Construction : 1960
10. Reference/Licensing deptt. letter no. (PFW/12)/2013/28192-94 /Addl.Cp/Lic.(Expl.) dated 07.06.13

S.NO.	Point of Inspection	Requirement	At Site	Remarks MR/NMI
1	Type of construction and floor area & floor level			
	a. Minimum floor area	9m2 (Min.)	20 m2	MR
	b. Construction	Pucca	Pucca	MR
	C. Premises Location	Not under the staircase/Mean of escape	Not under the staircase/Mean of escape	MR
	d. Business permissible only at ground floor level	Required	Ground Floor	MR
	e. Business from pavement of road prohibited	prohibited	Yes	MR
2	Entrance & Exits to the licensed premises			
	The licensed premises shall have independent entrance and exit	Required	independent entrance and exit	MR

*Handwritten notes and signatures at the bottom of the page.*



1RN/2

3	Type and distance of the surrounding risk			
	The premises shall be situated at a distance of 15 m from any such premises used for similar explosives/inflammable or hazardous materials.	Required 15 m	Yes	MR
4	Nature of business run in the licensed premises			
	The premises in which fireworks are kept shall be used only for possession and sale for fireworks and no other purposes.	Required	No other trade	MR
5.	Type of electrical wiring and electrical fittings			
	a. Preferably concealed or through conduit	Required	Concealed	MR
	b. All electrical fitting should be flame/spark proof	Required	Provided with casing & capping	MR
6	Extension of Shop for Business.			
	Prohibited	Prohibited	Yes	MR
7	Approach Road			
	The road width on the side of which premises is located should be 12m.	12 M	25 M	MR
8	Fire Protection Arrangement.			
	a) Extinguishers (Type & No's.)	1 no.water type & 1 no. of ABC/Co2 type	1 no.water type & 1 no. of ABC/Co2 type	MR
	b) Sand and Water Buckets	2 nos. each	2 nos. each	MR
	c) Water Drum(s)	1 no.	50 ltrs.	MR
9	Any other point that is contrary to the safety of people.			
			NIL	

The fire protection systems provided in shop were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

*Singh*  
12.8.13

Signature of the Inspecting Officer  
Name: *Suresh Singh*

DO/East