

DF

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, E-mail: cfohq.dfire@nic.in, Tel:- 011-23414333

NO.F6/DFS/MS/school/2013/ *NO2/789*

Dated: *23 / 08 / 13*

FIRE SAFETY CERTIFICATE

Certified that **Bhagwati Devi Shishu Bharti School, 280, Phtak Karor, Ajmeri Gate Bazar, Delhi-6** comprised of ground floor, mezzanine plus two upper floors was granted NOC vide letter no F.6/DFS/MS/2007/3388 dated 06-11-2007. The school premises was re-inspected by the officer concerned of this department on 22.07.2013 in presence of Mrs. Simmi Oberoi, Manager of the school and found that the School management have complied with fire prevention and fire safety requirements in accordance with the Delhi Fire Service Act-2010 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the following conditions.

Issued on ----- at New Delhi by.

Dr. G.C. Misra
(Dr.G.C. Misra)
Chief Fire Officer
Delhi Fire Service

9/8

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Bhagwati Devi Shishu Bharti School, 280, Phtak Karor, Ajmeri Gate Bazar, Delhi-6

Conditions for the validity of fire safety certificate

7. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
8. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
9. The trained staff should be available round the clock.
10. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
11. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
12. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Bhagwati Devi Shishu Bharti
280-Phatak Karor, Ajmeri Gate, Delhi-6
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F.6/DFS/MS/2007/3388 Dated 06/11/2007
5. Fire Safety directives Letter No. : NIL
6. Date of inspection : 22/9/13
7. Name of the Inspecting Officer : S.K. Tomar
8. Name and designation of Officer from the building side : Mrs. Simmi Oberoi (Manager)
9. Year of Construction : Starting Year 2006
10. Applicant's letter No. : NIL dated 26-09-2012

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr (Kutchapati Ram)	MR
	• Gate width	1.40 mtrs.	1.40 mtrs	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Two	Two	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases		Provided	MR
	• Upper floors	103cm & 93cm	103cm & 93cm	
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	N/A	N/A

3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	08	9 (Nine)	M/R
	• Types	CO ₂ (U.S.Ky) ABC ISI marked Powder	Provided	M.R.
	• IS marking		Provided	M.R.
6.	First - Aid Hose Reels			
	• Total numbers on	Two	Two	M.R.
	• Length of hose reel hose	30 mtr	Provided	M.R.
	• Nozzle diameter	5mm	Provided	M.R.
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Not Required	Provided	M/R
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A

Bhagwati Devi Shishu Bharti, Ajmeri Galt, Delhi 6

	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	M.R.
	• Number of hydrants per floor	Not (Not Reqd)	Two Provided	M.R.
	• Hose Box	Not Reqd.	Two Provided	M.R.
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A	N/A	N/A
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	450 LPM	Provided	MR
	➤ Discharge of pump	40 M	Provided	MR
	➤ Head of the pump	Required	Provided	MR
	➤ Power supply	Required	Switch Provided	MR
	➤ Auto starting of pump	Required	Switch Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5000 ltrs	Provided	M.R.
15	Exit Signage	Required	Provided	M.R.

8

16. Provision of Lifts				
➤	Pressurization of Lift Shaft	N/A	N/A	N/A
➤	Pressurization of lift lobby	N/A	N/A	N/A
➤	Communication in lift Car	N/A	N/A	N/A
➤	Fireman's Grounding Switch	N/A	N/A	N/A
➤	Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area			
➤	Total area	N/A	N/A	N/A
➤	Location	N/A	N/A	N/A
19.	Fire control room			
➤	Detector system panel	N/A	N/A	N/A
➤	Flow Switch Panel	N/A	N/A	N/A
➤	PA System Panel	N/A	N/A	N/A
➤	Batter backup	N/A	N/A	N/A
➤	Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted at serial numbers~~

.....

Signature of the Inspecting Officer

Name

Signature of the Inspecting Officer

Name Sanjay K. Tomar