

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/EH/2013/W2/831

Dated: 02/09/13

**FIRE SAFETY CERTIFICATE**

Certified that the Haldiram's located at 19 - A, Shivaji Marg, Nazafgarh Road, Moti Nagar, New Delhi - 110015 comprised of Basement, Ground plus Two Upper Floors with restaurants on Ground Plus Two Upper Floors was issued FSC vide letter no. F.6/DFS/MS/EH/2010/215 dated 20-01-2010, the premises was reinspected by the officers concerned of this department on 08.08.2013 in the presence of Mr. Udit Awasthi and found that the said Restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly Building" Group D of Sub Division-D 5 with effect from 02/09/13 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on 02/08/13 at New Delhi by.




(Santokh Singh)  
Chief Fire Officer,  
Delhi Fire Service.

Email: [cfowz.dfire@nic.in](mailto:cfowz.dfire@nic.in)

Ph: 011 - 23414250

Copy to:

1. M/s Haldiram's,  
19 - A, Shivaji Marg, Nazafgarh Road,  
Moti Nagar, New Delhi - 110015
2. The Dy. Health Officer, Health Department,  
West Zone, Rajouri Garden, New Delhi.

  
g/c  
Recd  
23/8/13

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

Re-inspection to see the compliance of shutcomings communicated vide letter no. F6/DPS/MS/EH/2013/1777 dated 11-07-13

**INSPECTION REPORT**

1. Name & address of the building: Haldiram's, 19A, Shivaji Marg  
Nazafgarh Road, Mohi Nagar, ND-15
2. Type of Occupancy : Assembly (B+G+2 upper floors)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F.6/DPS/MS/EH/2010/215 dated 20-1-10
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 08-08-2013
7. Name of the Inspecting Officer : Mukesh Verma ADO(MN) & Sunil Choudhary  
DO(West)
8. Name and designation of Officer Sh. Udit Anashti  
from the building side :
9. Year of Construction : -
10. Applicant's letter No. : Nil dated 23-07-13

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	<u>Accessible</u>	<u>Provided</u>	<u>MR</u> <u>-</u>
	• Gate width	<u>Accessible</u>	<u>Provided</u>	<u>MR</u> <u>-</u>
	• Width of internal road	<u>N/A</u>	<u>N/A</u>	<u>N/A</u> <u>-</u>
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	<u>2</u>	<u>Provided</u>	<u>MR</u> <u>-</u>
	• Basements	<u>2</u>	<u>Provided</u>	<u>MR</u> <u>-</u>
	b. Width of staircases			
	• Upper floors	<u>Old Case</u>	<u>Old Case</u>	<u>Old Case</u> <u>-</u>
	• Basements	<u>Old Case</u>	<u>Old Case</u>	<u>Old Case</u> <u>-</u>
	c. Protection of exits			
	• Fire check door	<u>Required</u>	<u>Provided</u>	<u>MR</u> <u>-</u>
	• Pressurization	<u>NR</u>	<u>NR</u>	<u>NR</u> <u>-</u>
	d. No of continuous staircase to terrace	<u>2</u>	<u>Provided</u>	<u>MR</u> <u>-</u>
	e. Width Of Corridor	<u>Old Case</u>	<u>Old Case</u>	<u>Old Case</u> <u>-</u>
	f. Door Size	<u>Old Case</u>	<u>Old Case</u>	<u>Old Case</u> <u>-</u>

3.	Compartmentation			
	• Fire check door	Required	Provided	MR /
	• Sealing of electrical shafts	Required	Provided	MR /
	• Fire Rating of shaft door	Required	Provided	MR /
	• Water Curtain	NA	NA	NA /
	• Fire Dampers	NA	NA	NA /
4.	Smoke managements System			
	• Basements	30 a/c per hour	Provided	MR /
	• Upper floors	12 a/c per hour	Provided	MR /
5.	Fire Extinguishers			
	• Total numbers	20 nos.	Provided	MR /
	• Types	ABC & CO2	Provided	MR /
	• IS marking	ISI marked	Provided	MR /
6.	First - Aid Hose Reels			
	• Total numbers on each floor	2	Provided	MR /
	• Length of hose reel hose	30m	Provided	MR /
	• Nozzle diameter	5mm	Provided	MR /
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Provided & functional	MR /
	• Location of Main Panel	Inside	Provided	MR /
	• Location of Repeater Panel	Inside	Provided	MR /
	• Alternate source of power	Required	Provided	MR /
	• Hooters' Location	Inside	Provided	MR /
8.	MOEFA	Required	Provided & functional	MR /
9.	Public Address System	NR	NR	NR /
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR /
	• Upper Floor	Required	Provided	MR /
	• Sprinkler above false ceiling	Required	Provided	MR /

11.	Internal Hydrants			
✓	• Size of riser/down-comer	100mm	Provided & functional MR	
	• Number of hydrants per floor	2	Provided MR	
	• Hose Box	2	Provided MR	
12.	Yard Hydrants			
	• Total number of hydrants	2	Provided MR	
	• Hose Box	2	Provided MR	
13.	Pumping Arrangements			
✓	• Ground Level			
	• Discharge of main pump			
	➤ Head of main pump			
	➤ Number of main pumps			
	➤ Jockey pump out put			
	➤ Jockey pump head		N/A	
	➤ Standby Pump out put			
	➤ Standby Pump Head			
	➤ Auto Starting/Manual stopping			
	➤ Pump House Access			
	• Terrace level	2x162alpm 1x180lpm	Provided & functional	MR
	➤ Discharge of pump	40m	Provided	MR
	➤ Head of the pump	Required	Provided	MR
➤ Power supply	Required	Provided	MR	
➤ Auto starting of pump	Required	Provided	MR	
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity			
	➤ Draw of connection			
	➤ Fire service inlet			
	➤ Access to tank			
	• Overhead Tank capacity	15,000lts.	Provided	MR
15	Exit Signage			
	Required	Provided	MR	
16.	Provision of Lifts			

M/24

	➤ Pressurization of Lift Shaft			
	➤ Pressurization of lift lobby			
	➤ Communication in lift Car			
	➤ Fireman's Grounding Switch		N/A	
	➤ Lift Signage			
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area			
	➤ Location		N/A	
19.	Fire control room			
	➤ Detector system panel			
	➤ Flow Switch Panel			
	➤ PA System Panel			
	➤ Batter backup		N/A	
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;		N/A	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue ~~shortcomings as noted at serial numbers~~



Signature of the Inspecting Officer

Name *Mukesh Verma*

Designation *ADO (MN)*

Signature of the Inspecting Officer

Name *Sunil Choudhary*

Designation *DO (West)*