

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

Ph.23414333, Fax:23412593,E-mail:cfohq.dlfire@nic.in

No. *f6/DFS/MS/School/2013/N02/834*

Dated: *03/09/13*

FIRE SAFETY CERTIFICATE

Certified that the Sneh International School, Junior, Jagriti Enclave, Vikas Marg, Extn., Delhi. Comprised of basement, ground plus one upper floor owned/occupied by Sneh International School have complied with the fire prevention and fire safety requirements in accordance with the circular no. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and verified by the officer concerned of Fire Service on 17.07.13 in the presence of Sh.Kamal Singh (Staff), of the school and that the building is fit for occupancy class B 'Educational Building' with effect from *03/09/13*..... for a period of three years, subject to conditions printed overleaf.

Issued on *03/09/13*..... at New Delhi by



(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

gc
29/13

To,
The President
Sneh International School, Junior,
Jagriti Enclave, Vikas Marg, Extn., Delhi -92.

Copy:-
The Dy. Director of Education
D-Block, Anand Vihar, Delhi.

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. Basement shall be used as per B.B.L.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1 RN-9

INSPECTION REPORT

1. Name & address of the building : Sneh International School, Junior , Jagriti Enclave, Vikas Marg Extn. , Delhi -94.
2. Building is comprised of : B,G +1 Upper floor
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous NOC letter : Nil
6. Fire Safety direction letter No : F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dtd. 01.03.11
7. Date of Inspection : 17.07.13
8. Name of the Inspecting officers : ADO Suresh Singh
9. Name and designation of Officer:
from the building side : Sh.Kamal Singh (staff)
10. Year of Construction - : 2011
11. Applicant's letter No : Dated 01.07.13

NO.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	06 M	06 M	MR
	• Gate width	4.5 M	4.5 M	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	01 No.	02 Nos.	MR
	• Upper Floor	01 No.	02 Nos.	MR
	• Basement	01 No.	1 no. of staircase with 2 exits	Acceptable
	B. Width of Staircases	1.5 M	1.10M, 0.80 M	Acceptable
	• Upper Floor	1.5 M	1.10M, 0.80 M	Acceptable
	• Basement	1.5 M	1 no. of staircase 1.10 m & 2 exits towards shunken area.	Acceptable
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01 No.	02 Nos.	MR
	g. Width of Corridor	1.5 M	1.5 M	MR
	h. Door Size	1.0 Mtrs	1.0 Mtrs	MR
	i. No. of doors in class room	1 No.	2 Nos.	MR

3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	6 Nos.	12 Nos.	MR
	• types	ABC ,Co2	ABC ,Co2	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	N/A	1No.	Acceptable
	• Length of hose reel hose	N/A	30 m	Acceptable
	• Nozzle diameter	N/A	5 MM	Acceptable
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement of 134 M2 only	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	100 MM	Acceptable
	• Number of hydrants per floor	N/A	1No.	Acceptable
	• Hose Box	N/A	1No.	Acceptable
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A

IRN-3

	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	Provided	Acceptable
	• Terrace Level	N/A	Provided	Acceptable
	➤ Discharge of pump	N/A	450 Lpm	Acceptable
	➤ Head of the Pump	N/A	40 M	Acceptable
	➤ Power supply	N/A	Provided	Acceptable
	➤ Auto Starting of pump	N/A	Auto	Acceptable
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	5000 ltrs.	Acceptable
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.



Singh
31/8/13

Signature of the Inspecting Officer

Name

Suresh Singh

Designation

ADD

DO (Fast)

submitted for approval please.

