

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFs/MS/2013/W2/851

Dated: 05/09/2013

FIRE SAFETY CERTIFICATE

Certified that the M C Primary Co-ed School is comprised of Ground Floor Only located at J Block, Sector-16, Rohini, Delhi-110089 owned/occupied by M C D Primary School, have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 06/06/2013 in the presence of Mrs. Saroj Singhal, (Principal) and that the building / premises is fit for occupancy of Educational building with effect from 05 / 09 /2013 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building bye laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 05.09.2013 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Principal, M.C Primary Co-ed School, J Block, Sector-16, Rohini, Delhi-110089
2. The Addl. Director of Education, North MCD, Civic Centre New Delhi.

Mo
(GF only)

INSPECTION REPORT

1. Name & address of the building : M C D Primary Co-ed School, J-Block, Sect-16, Rohini, Delhi
2. Type of Occupancy : Education
3. Type of Case : New Case
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : Director of Education.
6. Date of inspection : 06/06/2013
7. Name of the Inspecting Officers : ADO (Rohini)
8. Name and designation of officers
from the building side : Mrs. Saroj Singhal (Principal)
9. Year of Construction : 1989
10. Applicant's letter No. : nil Dated 02/04/2013

PA-9389.55 mtr, CA-15345mtr., Yards, Nos-744, NOT-21, NOR-21

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DoE NBC Requirement <i>(Clause 1.3.1)</i>	Provided at site	Remarks MR/NMR
1	Access to building	Old case		
	• Road width	Accessible	6m	M/R ✓
	• Gate width	Accessible	3.5 mtr	M/R ✓
	• Width of internal road	Accessible	Open area	M/R ✓
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	N.A.	N.A.	N.A.
	• Upper Floors	N.A.	N.A.	N.A.
	• Basements	N.A.	N.A.	N.A.
	b. Width of staircases	N.A.	N.A.	N.A.
	• Upper Floors	N.A.	N.A.	N.A.
	• Basements	N.A.	N.A.	N.A.
	c. Protection of exits	N.A.	N.A.	N.A.
	• Fire check door	N.A.	N.A.	N.A.
	• Pressurization	N.A.	N.A.	N.A.
	d. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	e. Width of Corridor	N.A.	N.A.	N.A.
	f. Door Size	1mtr	1 mtr	M/R ✓

W/n

12	Yard Hydrants.			
	• Total number of hydrants	N.A.	N.A.	N.A.
	• Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey Pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby Pump out put	N.A.	N.A.	N.A.
	➤ Standby Pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting/ Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace level			
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the pump	N.A.	N.A.	N.A.
	➤ Power Supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N.A.	N.A.	N.A.
	➤ Draw-off connection	N.A.	N.A.	N.A.
	➤ Fire service inlet	N.A.	N.A.	N.A.
	➤ Access to tank	N.A.	N.A.	N.A.
	• Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.			
		N.A.	N.A.	N.A.
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	• Pressurization of Lift lobby	N.A.	N.A.	N.A.
	• Communication In lift Car	N.A.	N.A.	N.A.
	• Fireman's Grounding Switch	N.A.	N.A.	N.A.
	• Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply			
		N.A.	N.A.	N.A.

M/S

18	Refuge Area.			
	➤ Total Area	N.A.	N.A.	N.A.
	➤ Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	• Detector System Panel	N.A.	N.A.	N.A.
	• Flow Switch Panel	N.A.	N.A.	N.A.
	• PA System Panel	N.A.	N.A.	N.A.
	• Batter backup	N.A.	N.A.	N.A.
	• Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....



Signature of the Inspecting Officer 06-8-13

Name N-P. SHARMA

Designation Assst. Div. offcr

Signature of the Inspecting Officer

Name

Designation