

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/2013/W2/854

Dated: 05 / 09 /2013

FIRE SAFETY CERTIFICATE

Certified that the Nigam Pratibha Vidyalaya, D - Block, Saraswati Vihar, Delhi is comprised of Ground + one floors owned/occupied by Nigam Pratibha Vidyalaya, D - Block, Saraswati Vihar, Delhi complied with the fire prevention and fire safety requirements in accordance with, the Circular No F.16/Estate/CC/Fire Safety/2011/3298 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on **23/07/2013** in the presence of **Smt. Usha Gupta (Principal)** and that the building / premises is fit for occupancy of **Educational** building with effect from 05 / 09 / 2013 for a period of **three years**, subject to compliance of conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupied shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 05.09.2013 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Head Mistress, Nigam Pratibha Vidyalaya, D - Block, Saraswati Vihar, Delhi.
2. The Director of Education, Govt. of NCT of Delhi.

- M/1-

(Ground + one floor only)

INSPECTION REPORT

1. Name & address of the building : Migam Pratibha Vidyalaya, D-Block Saraswati Vilas
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. Dated:
5. Fire Safety directives letter No : D.O.E. Circular dt. 01/03/2011
6. Date of inspection : 23/7/2013
7. Name of the Inspecting Officers : ADO(WP), S.I.C. DUG
8. Name and designation of officers from the building side : Smt. Usha Gupta, Principal
9. Year of Construction : 2006
10. Applicant's letter No. : Nil dated 19/7/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE NBE Requirement CIRC DT 1.3.11	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mtr.	Provided	MR
	• Gate width	Required	Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 (Two)	04 (Four)	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mtr.	1.5 mtr & 1.7 mtr	MR
	• Basements	NA	1.3 mtr & 1.3 mtr	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	Required	Two Provided	MR
	g. Width of Corridor	Required	2.43 mtr	MR
	h. Door Size	1.0 mtr.	1.1 mtr	MR

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		N/A	
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N/A	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types DCP/ABC-5kg. • IS marking 	11 (Eleven) ISI marked	15 (Fifteen) provided provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	N/A	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		N/A	
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 		N/A	
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	NA	NA

- N/B -

	<ul style="list-style-type: none"> • Number of hydrants per floor • Hose Box 		N/A	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 		N/A	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 		N/A	
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		N/A	
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby 		N/A	

- N/A -

	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area		N/A	
	➤ Location			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:	No		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~



Signature of the Inspecting Officer

Name

S.K. Dua

Designation

ADO (WP)

Signature of the Inspecting Officer

Name

Designation