

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2013/859

Dated: 05 / 09 /2013

**FIRE SAFETY CERTIFICATE**

Certified that the Mata Jai Kaur Public School, Ashok Vihar, Phase -III, Delhi-110052 comprised of basement, Ground + two upper floors occupied by Mata Jai Kaur Public School, Ashok Vihar, Phase -III, was issued NOC vide this office letter no. F.6/MS/ DFS/2008/2494 dated 01/09/2008. The premises was re-inspected by the officer concerned of this department on 12/08/2013 in the presence of **Col.(Retd.) Ashok Kaul, Principal**, and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the Director of Education circular Dated 01/03/2011 and the building/ premises is fit for occupancy Class **Educational** with effect from 05 / 09 /2013 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. Basement shall be used as per NBC.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupied shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on 05/09/13 at New Delhi

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
[cfowz.dlfire@nic.in](mailto:cfowz.dlfire@nic.in)

**Copy to:**

1. The Principal, Mata Jai Kaur Public School, Ashok Vihar, Delhi.
2. The Director of Education, Govt. of NCT of Delhi.



- M4 -  
B, G + Two upper floors.

Basement is being used for storage purpose only.

**INSPECTION REPORT**

1. Name & address of the building : Mata Jai Kaur Public School, Ashok Vihar - III, Delhi - 52
2. Type of Occupancy : Educational
3. Type of Case : New Case / Renewal
4. Details of previous NOC : Letter No. F6/MS/DSS/2008/2494 Dated: 01/09/2008
5. Fire Safety directives letter No : \_\_\_\_\_
6. Date of inspection : 12/08/2013
7. Name of the Inspecting Officers : D.O. S.K. DUG
8. Name and designation of officers from the building side : Col. (Retd.) Ashok Kaul
9. Year of Construction : \_\_\_\_\_
10. Applicant's letter No. : MIL dated 16/04/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6 mtr	Provided	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	5 + Ramp	Provided	MR
	• Basements	Two	Two	MR
	b. Width of staircases			
	• Upper Floors	old case	1) 1.15m 2) 1.48m	3) 1.30m - old case
	• Basements	old case	1) 1.40m 2) 1.28m	
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	Two	Provided	MR
	g. Width of Corridor	1.5 mtr	2.35 mtr	MR
	h. Door Size	1.0 mtr	1.05 mtr	MR

- 175 -

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>		N/A	
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	Exhaust Fans Provided Open to sky	MR MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	ISI marked		
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	Two 30 m 5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>		N/A	
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	Required	Provided N/A	MR
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	NR 100 mm	Provided	MR

- N/6 -

	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NR	Two provided	NR
		NR	provided	NR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>		MA	
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level               <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level               <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>		N/A	
		450 LPM	provided	MR old case -
		40 mtr	-do-	-do-
		Required	-do-	MR
		Required	-do-	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>		N/A	
		15,000 Lts.	provided	MR
	Supp X3 = Lts.	Required	provided	MR
15	<b>Exit Signage.</b>	Required	provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> </ul>		N/A	

-N/A-

	<ul style="list-style-type: none"> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>			
17	Standby power supply	Repaired	Provided (D.G. set)	MR
18	Refuge Area.			
	➤ Total Area			
	➤ Location		N/A	
19	Fire Control Room			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>			
20	Special Fire Protection Systems for Protection of special Risks, if any:	No	-	-



The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....

Signature of the Inspecting Officer *S. Ic. Dua*  
 Name *S. Ic. Dua*  
 Designation *Div. Officer*

Signature of the Inspecting Officer  
 Name  
 Designation