


NO. F6/DFS/MS/School/2013/ SZ/ 862

DATED: 05/08/13

**FIRE SAFETY CERTIFICATE**

Certified that the Rishikul Internation School ( Kapila Public Education, Social & Cultural Society) at plot No. 3, Sector-7 Dwarka, New Delhi-110075, comprised of basement ground plus two upper floors was granted NOC by this department vide letter no. F6/MS/DFS/2005/1094 dated 27.05.2005. The premises was re-inspected by the officers concerned of this department on 26.08.2013 in the presence of Mrs. Amita Sood and observed that fire safety norms as required under Rule 33 of Delhi Fire Service Rules, 2010 are deemed complied and that the building / premises is fit for occupancy class B "Educational building" with effect from...05/08/13... for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on ...05/08/13... at New Delhi by

  
(Dr. G.C. Misra)  
Chief Fire Officer  
Delhi Fire Service

Copy to,

1. The Dy. Director, (Education), G.N.C.T..of Delhi, Old Secretariat, New Delhi-110054.
2. Mr. V. P. Tandon (Secretary), Rishikul Internation School ( Kapila Public Education, Social & Cultural Society) at plot No. 3, Sector-7, Dwarka, New Delhi-110075.

**Conditions for the validity of fire safety certificate**

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1	Name & address of the building	Rishikul International School ( Kapila Public Education, Social & Cultural Society) at plot No. 3, Sector-7 Dwarka, New Delhi-110075		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/MS/DFS/2005/1094 dated 27.05.2005. ( <b>Basement ground plus one upper floor</b> )		
5	Fire safety directives letter No	F6DFS/MS/BP/2012/4266 Dated 14.11.2012		
6	Date of inspection	27.08.2013		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Mrs. Amita Sood (Principal)		
9	Year of construction			
10	Applicant's letter No.	KPESCS/550 Dated 4.7.2013	<b>(Basement ground plus two upper floors)</b>	
			Old Case	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	<b>Access to building</b>			
	1) Road width	Required	30 Mtr Provided	MR
	2) Gate width	Required	5 Mtr Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	Old Case	2 Nos. Provided	MR
	2. basements	Old Case	1 No. Provided	MR
	<b>b. Width of staircase</b>			
	1. Upper floors	Old Case	1.50 Mtr each Provided	MR
	2. basements	Old Case	1.50 Mtr Provided	MR
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	One Provided	MR
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	Old Case	1 Mtr Provided	MR
3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Vent.	MR

5	<b>Fire Extinguishers</b>		9 Nos	MR	
	total numbers			Co2 & ABC	MR
	Types			Provided	MR
	ISI marking	ISI			
6	<b>First-Aid Hose Reels.</b>				
	total numbers on each floor	Required	One Provided	MR	
	Length of Hose reel hose	30 m	Provided	MR	
	Nozzle Diameter	5 mm	Provided	MR	
7	<b>Automatic fire detection and alarming system</b>				
	Type of detectors	N/A	N/A	N/A	
	location of Main Panel	N/A	N/A	N/A	
	location of Repeater panel	N/A	N/A	N/A	
	Alternate source of power	N/A	N/A	N/A	
	hooter's location	N/A	N/A	N/A	
8	<b>MOEFA</b>	N/A	N/A	N/A	
9	<b>Public Address System.</b>	Required	Provided	MR	
10	<b>Automatic Sprinkler System.</b>				
	basement	N/A	N/A	N/A	
	upper floors	N/A	N/A	N/A	
	sprinkler above false ceiling	N/A	N/A	N/A	
11	<b>Internal Hydrants</b>				
	Size of riser/down-corner	N/A	100 MM Provided	MR	
	Number of Hydrants per floor	N/A	One Provided	MR	
	hose Box	N/A	One Provided	MR	
12	<b>Yard Hydrants.</b>				
	total number of hydrants	N/A	N/A	N/A	
	hose box	N/A	N/A	N/A	
13	<b>Pumping arrangements</b>				
	<b>1. Ground level</b>				
	a. Discharge of main Pump	N/A	N/A	N/A	
	b. Head of main pump	N/A	N/A	N/A	
	c. Number of main pumps	N/A	N/A	N/A	
	d. jockey pump out put	N/A	N/A	N/A	
	e. jockey pump head	N/A	N/A	N/A	
	f. Standby Pump output	N/A	N/A	N/A	
	g. Stanby Pump head	N/A	N/A	N/A	
	h. Auto Starting/Manual stopping	N/A	N/A	N/A	
	pump house access	N/A	N/A	N/A	
	<b>2. Terrace level</b>				
	a. Discharge of pump	Old Case	450 LPM Provided	MR	
	b. head of the pump	Old Case	35 Mtr Provided	MR	
	c. Power supply	Required	Provided	MR	
	d. Auto starting of pump	Required	Provided	MR	
14	<b>Captive water storage for fire fighting</b>				
	1. Underground tank capacity	N/A	N/A	N/A	
	a. Draw-off connection	N/A	N/A	N/A	
	b. fire service inlet	N/A	N/A	MR	
	c. Access to tank	N/A	N/A	N/A	
	Over head tank Capacity	Required	10,000 Ltr Provided	MR	
15	<b>Exit Signage.</b>	Required	Provided	MR	

*[Handwritten signature]*

16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>	Not Required		
	total area			
	location			
19	<b>Fire control room</b>			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special risks, if any:</b>	N/A		

**The Management has constructed one new floor of class rooms. The required fire safety arrangement is provided which meets the requirement.**

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/

**Accordingly DFA is put up for your approval and signature please.**

Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)