

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2013/W2/878

Dated: 06/09/2013

**FIRE SAFETY CERTIFICATE**

Certified that the Building at Plat No. D-10, Udyog Nagar, Rohtak Road, New Delhi-110041, comprised of **Basement + Ground + Mezzanine + First Floor only** owned / occupied by **Micro Footwears Pvt. Ltd.**, has already been issued Fire Safety Certificate **vide letter No.F6/MS/DFS/2000/940 dated 01.06.2000.** The premises / Building was re-inspected by the officer concerned of Fire Service on **10.08.2013** in the presence of **Sh. J.K. Aggarwal (Partner)** and found that building / premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class **Industrial** with effect from 06/09/2013 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

**Issued on** 06/09/13 **at New Delhi by.**

  
**(SANTOKH SINGH)**  
**CHIEF FIRE OFFICER**  
**DELHI FIRE SERVICE**  
**Phone:-23414250**  
**E-mail: cfowz.dlfire@nic.in**

Copy to :-

1. Sh. J.K. Aggarwal, Micro Foot wears Pvt. Ltd., C-2, Udyog Nagar, Rohtak Road, New Delhi-110041 .

Basement  
G Floor  
Mezzanine Floor  
1st Floor

Plot Area = 2641 m<sup>2</sup>

NF

**INSPECTION REPORT**

1. Name & address of the building: D-10, Udyog Nagar, Rohtak Road  
Delhi - 110041
2. Type of Occupancy : Industrial
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F-6 / MS / DFS / 2000 / 940 / 1-6-2000
5. Fire Safety directives Letter No. : F6 / DFS / MS / RP / 89 / 155 / 3 / 2 / 1989
6. Date of inspection : 10 / 8 / 2013
7. Name of the Inspecting Officer : A. K. Jaiswal
8. Name and designation of Officer  
from the building side : J. K. Aggarwal
9. Year of Construction : 1988
10. Applicant's letter No. : Nil dated 10/7/13

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL / NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6	Provided	MR
	• Gate width	5	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	2	4	MR
	b. Width of staircases			
	• Upper floors	old case	old case	old case
	• Basements	old case	old case	old case
	c. Protection of exits			
	• Fire check door			
	• Pressurization		NR	
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	old case	old case	old case
	f. Door Size	1.20 Mtr.	Provided	MR

N/S

3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>			
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	Exhaust Fans Provided	MR
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	Exhaust Fans Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	25	Provided	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC/CO <sub>2</sub> /Foam ISI marked WCO <sub>2</sub>	Provided	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>		Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	2	Provided	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 Mtr.	Provided	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detector</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>			
8.	MOEFA	Not Required	Provided	MR
9.	Public Address System		NR	
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>		NR	
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>		NR	

M/g

11.	Internal Hydrants			
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	2	Provided	MR
	• Hose Box	2	Provided	MR

12.	Yard Hydrants			
	• Total number of hydrants		<del>NR</del>	
	• Hose Box			

13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	2280 lpm	Provided	MR
	➤ Head of main pump	60 MH	Provided	MR
	➤ Number of main pumps	1	Provided	MR
	➤ Jockey pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	40 MH	Provided	MR
	➤ Standby Pump out put			
	➤ Standby Pump Head		<del>NR</del>	
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump			
	➤ Head of the pump			
	➤ Power supply		<del>NR</del>	
	➤ Auto starting of pump			

14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	1,00000	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	15000 lts	Provided	MR

11/10

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft			NR
	➤ Pressurization of lift lobby			
	➤ Communication in lift Car			
	➤ Fireman's Grounding Switch			
	➤ Lift Signage			
17.	Standby power supply	Not Required	Provided	MR
18.	Refuge Area			
	➤ Total area			NR
	➤ Location			
19.	Fire control room			
	➤ Detector system panel			NR
	➤ Flow Switch Panel			
	➤ PA System Panel			
	➤ Batter backup			
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;	At DG set, Foam fire Ext. Required	Provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/~~issue shortcomings as noted at serial numbers.~~

.....

N/11

AK Jaiswal

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

(A.K. JAISWAL)

Name

Designation

ADO (JWP)

Designation